





NOTES

1. ALL WORK TO BE DONE IN ACCORDANCE WITH SANS 1200 LATEST VERSION
2. ALL LEVELS TO BE SET-OUT FROM BENCH MARK INDICATED ON SHEET 01
3. TOP OF EQUIPMENT FOUNDATIONS TO BE 150mm ABOVE TERRACE LEVEL
4. ALL FOUNDATION HOLDING DOWN BOLTS TO BE ALIGNED FOR CASTING OF CONCRETE TO A TOLERANCE OF $\pm 2mm$. FOUNDATION TOLERANCE TO BE IN ACCORDANCE WITH SANS 1200 G6 GRADE II
5. DEPTH OF EQUIPMENT FOUNDATIONS TO BE NOT LESS THAN SHOWN ON DETAIL DRAWING AND NOT LESS THAN 300mm INTO NATURAL GROUND
6. ALL TOP EDGES OF CONCRETE ABOVE GROUND LEVEL TO HAVE 25mm CHAMFER AT 45°. ONLY STEEL SHUTTERING CAN BE USED.
7. ALL FOUNDATIONS TO BE CAST WITH 50x3mm FLAT COPPER BAR BOLTED TO FOUNDATION BOLTS AS SHOWN ON THE APPROPRIATE DRAWINGS. A LENGTH OF 2m TO PROTRUDE OUTSIDE THE FOUNDATION FOR CONNECTING TO THE MAIN EARTHMAT ON INSTALLATION
8. ALL EXPOSED FOUNDATION SURFACES SHALL BE STEEL FLOAT FINISHED
9. ----- CONTROL CABLES ROUTES
10.  MW CABLE WITH ROUTE MARKERS
11.  PILOT CABLE ROUTE (MW CABLE PROTECTION)
12.  LIGHTS TO OPERATE ON DAY LIGHT SWITCH AND BALANCE OF LIGHT TO BE OPERATED NORMALLY

1. ALL WORK TO BE DONE IN ACCORDANCE WITH SANS 1200 LATEST REVISION
2. ALL LEVELS TO BE SET-OUT FROM BENCH MARK INDICATED ON SHEET 01
3. TOP OF EQUIPMENT FOUNDATIONS TO BE 150mm ABOVE TERRACE LEVEL
4. ALL FOUNDATION HOLDING DOWN BOLTS TO BE ALLOWED FOR CASTING OF CONCRETE TO A TOLERANCE OF ± 2 mm. FOUNDATION TOLERANCE TO BE IN ACCORDANCE WITH SANS 1200 06 GRADE II
5. DEPTH OF EQUIPMENT FOUNDATIONS TO BE NOT LESS THAN SHOWN ON DETAIL DRAWING AND NOT LESS THAN 300mm INTO NATURAL GROUND
6. ALL TOP EDGES OF CONCRETE ABOVE GROUND LEVEL TO HAVE 25mm CHAMFER AT 45C. ONLY STEEL SHUTTERING CAN BE USED.
7. ALL FOUNDATIONS TO BE CAST WITH 50x3mm FLAT COPPER BAR BOLTED TO FOUNDATION BOLTS AS SHOWN ON THE APPROPRIATE DRAWINGS. A LENGTH OF 2m TO PROTRUDE OUTSIDE THE FOUNDATION FOR CONNECTING TO THE MAIN EARTH MAT ON INSTALLATION
8. ALL EXPOSED FOUNDATION SURFACES SHALL BE STEEL FLOAT FINISHED
9. - - - - - CONTROL CABLES ROUTES
10. - - -  - - - MW CABLE ROUTE MARKERS
11. - - - - - PILOT CABLE ROUTE (MW CABLE PROTECTION)
12. - - - - - LIGHTS TO OPERATE ON DAY LIGHT SWITCH AND BALANCE OF LIGHT TO BE OPERATED

[illegible]