

QUESTION	RESPONSE
The Functionality Criteria has also requested for a minimum of five projects as experience for civil works (page 12 of 28).Are we to include project award and completion certificates as evidence	Completion certificate acceptable
The functionality Criteria, also does not make provision for an approved authorised person with HV Regs,Will this responsibility be assumed by Eskom, or is not required?	Work will be done next to live apparatus which is the mobile substation once it get connected. An Authorised person is required.