


NOTE: DRAWING NOT FOR MANUFACTURING PURPOSES


CODE	DIA "A" (mm)	PCD (mm)	RATED VOLTAGE (kV)	SAP NUMBER
EXCP-A	26.5	76	145	0401673
EXCP-B	26.5	127	145	0401675
EXCP-C	38.3	76	145	0401677
EXCP-D	38.3	127	145	0401679

ITEM		:-		POST INSULATOR MOUNTED SINGLE CONDUCTOR BOLTED SUPPORT CLAMP;					
MATERIAL SPECIFICATION		:-		AL ALLOY< 0.1% CU (240-53113927)					
CORROSION SPECIFICATION		:-		240-53113927					
STANDARD SPECIFICATION		:-		240-53113927					
ESKOM SPECIFICATION		:-		240-53113927					
TEST & CERTIFICATION REQUIREMENTS		:-		240-53113927					
INSPECTION		Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS									
6	CLAMP DESCRIPTIONS, MATERIAL AND ALL SPECIFICATION REFERENCES UPDATED			Justice Shinta	Dickey van Eeden	Theunus Marais	23.02.2021		
5	SAP 0005212, 0005213, 0005214, 0005215 CORRECTED			P.A.T.	D.RAMJASS	D.RAMJASS	26.01.2017		
4	LOGO IN TITLE BLOCK CHANGED AS PER CORPORATE IDENTITY.			VvZ	C.B.C.	C.CLARK	16/02/2004		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DRAWINGS	
AUTH:	PHIL CROWDY	DATE:	12/96	SCALE	 Eskom		SAP No:		
				NTS					
				CAD REF:					
CHKD:	C.B. CLARK	DATE:	12/96	SERIES 6000	D-DT-6029		SET	SHEET	REV
				FILE No:			2	1	6
				6029					

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:		0401673					
SHORT DESCRIPTION:		CLAMP:EXCP-A;PI MOUNT;26.5 MM;PCD 76					
TECH. DESCRIPTION:							
CLAMP: EXCP-A; TYPE: PI MOUNT; CONDUCTOR SIZE: 26.5 MM; DIMENSIONS: PCD 76; MAXIMUM OPERATING POTENTIAL: 145 KV; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). ESKOM DRAWING No. D-DT-6029 *							
SAP MATERIAL No.:		0401675					
SHORT DESCRIPTION:		CLAMP:EXCP-B;PI MOUNT;26.5 MM;PCD 127					
TECH. DESCRIPTION:							
CLAMP: EXCP-B; TYPE: PI MOUNT; CONDUCTOR SIZE: 26.5 MM; DIMENSIONS: PCD 127; MAXIMUM OPERATING POTENTIAL: 145 KV; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). ESKOM DRAWING No. D-DT-6029 *							
SAP MATERIAL No.:		0401677					
SHORT DESCRIPTION:		CLAMP:EXCP-C;PI MOUNT;38.3 MM;PCD 76					
TECH. DESCRIPTION:							
CLAMP: EXCP-C; TYPE: PI MOUNT; CONDUCTOR SIZE: 38.3 MM; DIMENSIONS: PCD 76; MAXIMUM OPERATING POTENTIAL: 145 KV; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). ESKOM DRAWING No. D-DT-6029 *							
SAP MATERIAL No.:		0401679					
SHORT DESCRIPTION:		CLAMP:EXCP-D;PI MOUNT;38.3 MM;PCD 127					
TECH. DESCRIPTION:							
CLAMP: EXCP-D; TYPE: PI MOUNT; CONDUCTOR SIZE: 38.3 MM; DIMENSIONS: PCD 127; MAXIMUM OPERATING POTENTIAL: 145 KV; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). ESKOM DRAWING No. D-DT-6029 *							
6	CLAMP DESCRIPTIONS, MATERIAL AND ALL SPECIFICATION REFERENCES UPDATED		Justice Shinta	Dickey van Eeden	Theunus Marais	23.02.2021	
5	SAP 0005212, 0005213, 0005214, 0005215 CORRECTED		P.A.T.	D.RAMJASS	D.RAMJASS	26.01.2017	
4	LOGO IN TITLE BLOCK CHANGED AS PER CORPORATE IDENTITY.		VvZ	C.B.C.	C.CLARK	16/02/2004	
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DRAWINGS
AUTH:	PHIL CROWDY	DATE:	12/96	 D-DT-6029		SAP No:	
CHKD:	C.B. CLARK	DATE:	12/96			0401673	0401677
						0401675	0401679
DRAWN:	J.F.SCHOLTZ	DATE:	10/96			SET	SHEET
				2	2	6	