


NOTE :
DRAWING NOT FOR MANUFACTURING PURPOSES.

SAP MATERIAL No.:		0017527						
SHORT DESCRIPTION:		INSUL:STN POST;C4-325;66 KV						
TECH. DESCRIPTION:								
INSULATOR: TYPE: STN POST; POTENTIAL: 66 KV; CANTILEVER STRENGTH: 4KN; LIWL (BIL) 350 KV; SPECIFIC CREEPAGE DISTANCE: 31 MM/KV; ESKOM DRAWING No. D-DT-6232 *								
ITEM		:- INSUL:STN POST;C4-325;66 KV						
MATERIAL SPECIFICATION		:- PORCELAIN						
CORROSION SPECIFICATION		:- SANS 121						
STANDARD SPECIFICATION		:- NRS 031:1993						
ESKOM SPECIFICATION		:- DSP 34-2202						
TEST & CERTIFICATION REQUIREMENTS		:- DSP 34-2202						
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
7	SHORT AND TECHNICAL DESCRIPTIONS CORRECTED ACCORDING TO PILOG/SAP			P.A.T.	M. SHUTER	G. STRELEC	27.03.2012	
6	0010307 OBSOLETE AND VARIOUS TERMINOLOGY CHANGES MADE ON 0017527 AND ESKOM SPEC & TYPE TESTS CHANGED			P.A.T.	G. STRELEC	V.SINGH	07.06.2011	
5	LOGO CHANGED AS PER NEW CORPORATE ID			AKM	J.F.S	C.CLARK	31/05/04	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	
AUTH:		PHIL CROWDY	DATE:	06/97	 D-DT-6232		SAP No:	
CHKD:		C.B. CLARK	DATE:	06/97			0017527	
DRAWN:		J.F.SCHOLTZ	DATE:	10/96			REV	
					SET	SHEET	REV	
					1	1	7	