


- NOTES:
- 1. CONCRETE WORK TO BE IN ACCORDANCE WITH SANS 1200.
 - 2. CONCRETE STRENGTH TO BE 35MPa, WITH AN AGGREGATE STONE SIZE OF 13mm.
 - 3. SLABS TO BE CAST IN STEEL MOULDS WITH END AND SIDES TAPERED 3°.
 - 4. REINFORCING TO HAVE A MIN CONCRETE COVER OF 20mm.
 - 5. NEWLY CAST SLABS TO BE THOROUGHLY COMPACTED BY USING A VIBRATOR TABLE.
 - 6. NO OTHER METHOD OF CONSTRUCTION AND/OR PREFABRICATED SLABS WILL BE ACCEPTED WITHOUT APPROVAL.

SCHEDULE OF QUANTITIES
CONCRETE = 0.030m ³
WEIGHT = 72kg

D-DT-5254	SHEET 6B	TRENCH COVER SUPPORT - 1500mm
D-DT-5254	SHEET 6A	TRENCH COVER SUPPORT - 750mm
D-DT-5254	SHEET 1B	TRENCH COVER - 1500mm
D-DT-5254	SHEET 1A	TRENCH COVER - 750mm
DRG NO.	SHEET NO:	REFERENCE DRAWINGS:

THIS DRAWING IS THE NEW OFFICIAL REVISION AND IT SUPERSEDES ALL OTHER PUBLISHED DRAWINGS						
0	FIRST ISSUE				/ /	
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.
		SUBSTATION TRENCH KERBING - 1000mm (CONCRETE)				
AUTH:	N WEBBER					
DATE:	13/08/2014					
CHKD:	B HLOMENDLIN					
SAP No. 0599535	DATE: 06/08/2014	D-DT-5254		SET	SHEET	REVISION
SCALE 1 : 10	DRAWN: G BEETGE				2A	0
THIS DRAWING IS THE PROPERTY OF ESKOM	DATE: 15/04/2014					