



- NOTES:
- 1 FOR 750mm TRENCH COVER SEE DRAWING D-DT-5254 SHT 1A.
  - 2 FOR TRENCH KERBING SEE DRAWING D-DT-5254 SHT 2A.
  - 3 FOR 750mm TRENCH BRACE SEE DRAWING D-DT-5254 SHT 6A.
  - 4 TRENCH KERBING TO BE PLACED ON CONCRETE FOOTING AS PER DETAIL.
  - 5 TRENCH KERBING TO BE INSTALLED WITH ROUNDED EDGE TO INSIDE OF TRENCH TO PREVENT CABLE DAMAGE.
  - 6 TRENCHES MUST NOT BE USED AS WALKWAYS.

D-DT-5254	SHEET 50	TRENCH 750 - CABLE TRENCH RAMP
D-DT-5254	SHEET 5N	TRENCH 750 - 'X' TO 750 - STRAIGHT 1500
D-DT-5254	SHEET 5M	TRENCH 1500 - 'X' TYPE A TO 1500
D-DT-5254	SHEET 5L	TRENCH 750 - 'X' TYPE B TO 750
D-DT-5254	SHEET 5K	TRENCH 750 - 'X' TYPE A TO 750
D-DT-5254	SHEET 5J	TRENCH 1500 - 'T' TO 1500
D-DT-5254	SHEET 5I	TRENCH 750 - 'T' TO 1500
D-DT-5254	SHEET 5H	TRENCH 750 - 'T' TYPE B TO 750
D-DT-5254	SHEET 5F	TRENCH 1500 - 90 DEG TYPE A BEND
D-DT-5254	SHEET 5E	TRENCH 750 - 90 DEG TYPE B BEND
D-DT-5254	SHEET 5D	TRENCH 750 - 90 DEG TYPE A BEND
D-DT-5254	SHEET 5C	TRENCH 750 - STRAIGHT TO 1500
D-DT-5254	SHEET 5B	TRENCH 1500 - STRAIGHT
D-DT-5254	SHEET 5A	TRENCH 750 - STRAIGHT
DRG NO.	SHEET NO.	REFERENCE DRAWINGS:

THIS DRAWING IS THE NEW OFFICIAL REVISION AND IT SUPERSEDES ALL OTHER PUBLISHED DRAWINGS						
					/ /	
0	FIRST ISSUE				/ /	
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.
		SUBSTATION TRENCH 750mm WIDE - 'T' TYPE A TO 750mm WIDE STRAIGHT INSTALLATION AND SECTIONS				
AUTH: N WEBBER	D-DT-5254					SET
DATE: 13/08/2014						
CHKD: B HLOMENDLINI						
DATE: 06/08/2014						
SCALE 1:20	DRAWN: G BEETGE	5G		0		REVISION
THIS DRAWING IS THE PROPERTY OF ESKOM	DATE: 15/04/2014					