


NOTE :

DRAWING NOT FOR MANUFACTURING PURPOSE.

SAP MATERIAL No.:		0017528						
SHORT DESCRIPTION:		INSUL:STN POST;C4-550;132 KV						
TECH. DESCRIPTION:								
INSULATOR: TYPE: STN POST; POTENTIAL: 132 KV; CANTILEVER STRENGTH: 4KN; LIWL (BIL) 550KV; SPECIFIC CREEPAGE DISTANCE 31MM/KV; ESKOM DRAWING No. D-DT-6230 *								
ITEM :- INSUL:STN POST;C4-550;132 KV								
MATERIAL SPECIFICATION :- PORCELAIN								
CORROSION SPECIFICATION :- SANS 121								
STANDARD SPECIFICATION :- NRS 031:1993								
ESKOM SPECIFICATION :- DSP 34-2202								
TEST & CERTIFICATION REQUIREMENTS :- DSP 34-2202								
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
7	SHORT AND TECHNICAL DESCRIPTIONS CORRECTED ACCORDING TO PILOG/SAP			P.A.T.	M. SHUTER	G. STRELEC	27.03.2012	
6	0010308 OBSOLETE AND VARIOUS TERMINOLOGY CHANGES MADE ON 0017528 AND ESKOM SPEC & TYPE TESTS CHANGED			P.A.T.	G. STRELEC	V.SINGH	07.06.2011	
5	LOGO CHANGED AS PER NEW CORPORATE ID			AKM	J.F.S	C.CLARK	31/05/04	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	
							REF. DRAWINGS	
AUTH:		PHIL CROWDY	DATE:	06/97	 <b>D-DT-6230</b>		SAP No:	
CHKD:		C.B. CLARK	DATE:	06/97			0017528	
DRAWN:		J.F.SCHOLTZ	DATE:	10/96				
							SET	SHEET
							1	1
								7