

**Date:**  
5 July 2022

**Enquiries:**  
Shilo Motuku  
Tel +27 13 647 9188  
Fax +27 86 537 3516  
Email shilo.motuku@eskom.co.za

## PART 1

### CLARIFICATIONS - ENQUIRY NO. MPKEN10276GX

**DESCRIPTION: - FOR THE REMOVAL AND REPLACEMENT OF SUPERHEATER FRONT PENDANT FINISHING RUL TUBES AT KENDAL POWER STATION UNIT 1 AND 3 GO.**

Supplier Clarification	Eskom Response
1. In NEC X1 there are no non-adjustable portion required for CPA, is this correct?	Though non-adjustable is not indicated on that page, it is indicated on page 6 of the Pricing Data, it was advised that the information on page 6 of the Pricing Data is the same information to be put on page 6 of the Data Provided by the Employer. Non-adjustable portion is also indicated on page 38 of the Invitation to Tender document.
2. In NEC X5.1 section 2 refers to Dipper plate replacement which are not a requirement as per the <i>Employers</i> works information. Please clarify requirements on dipper plates.	It is an error, we will not be doing Deeper plates on this project. Will be amended accordingly.
3. Clause NEC X7.1 also refers to dipper plates which is excluded from <i>Employers</i> works information.	It is an error, we will not be doing Deeper plates on this project. Will be amended accordingly.
4. From tender information we notice that anticipated contract start date is 01 Nov 2022 with first outage later in 2023 as per current outage schedule. From this we request an extension to the submission date ( $\pm 10$ days) to allow <i>Contractors</i> to provide Eskom with a technical and commercial compliant tender.	Extension will be granted.  The new tender closing date is 28 July 2022.
5. The scope of work makes no mention of SA 213 Gr 347 to SA 213 Gr 347 welds which are anticipated during welding on site.	catered for in the price of bill
6. The scope is priced on a cost per butt weld basis. However, attachment welds are expected which do not form part of the butt weld cost. Where should the contractor allow for this cost?	catered for in the price of bill