

TENDER NUMBER: **E1514GXGPLET-R**

TENDER DESCRIPTION: **SUPPLY AND DELIVERY OF MILLING PLANT SPARES WEAR PROTECTION (CATEGORY 3) FOR A PERIOD OF FIVE (5) YEARS FOR STOCK REPLENISHMENT AT LETHABO POWER STATION.**

CLOSING DATE: **30 July 2025 @ 10:00am**

CLARIFICATION CLOSING DATE: **Five (5) working days before the deadline for tender submission.**

	QUESTION	ANSWER
1.	Specification of tender that it is not attached on the tender document.	Eskom Bulletin: Specification is included on the NEC3 document. eTenders: NEC3 is attached in a zip folder.
2.	Drawings	Please note that there are no drawings available for these items. The material description provided should be technically sound and sufficient to outline the required materials. Further clarity will be given at the clarification meeting. Link available on the invitation to tender (ITT).