

**ADDENDUM NO.1****ESSELEN BYPASS TENDER NOMWP 1443 TX**

CLARIFICATION NO 1

DATE : 13 JULY 2022

<b>SUPPLIERS CLARIFICATION</b>	<b>ESKOM's RESPONSE</b>
<b>BOQ &amp; SCOPE</b>	
1.Type and Make of 132kV and 275kV <b>Isolators</b> to be Erected	Isolators are from Actom and are motorised
2. Is the <b>Tubular Busbars</b> not part of this scope?	Installation of Tubular BB is not part of the Scope
3. BOQ is on PDF format	Suppliers to price BOQ as provided by our internal QS.
<b>SHEQ REQUIREMENTS</b>	
<b>Quality &amp; Environmental Requirements</b>	All Quality and Environmental requirements was re-downloaded to Eskom Tender Bulletins after it previously failed to download
<b>Safety &amp; Health Requirements</b>	Eskom unfortunately delayed on redefining these requirement and addendum to this section will be posted shortly on the Tender bulletins and <b>no suppliers will be disqualified for SHEQ requirements</b> although it is important that they all be proposed as per the each evaluation criteria provided.
<b>Time extension</b>	Site meeting was regrettably cancelled due to unforeseen circumstances internally and <b>it can not be rescheduled</b> owing to project schedule constrains on the current schedule approvals, <b>nor any time extension can be possibly granted over the same reason</b>