

ADDENDUM 1

Date: 21 JULY 2022

Ref: MPKUS10324GX -
Addendum 3 Enquiries: Romeo
Mokwena
Email: MokwenRJ@eskom.co.za

To whom it may concern

SUPPLY AND DELIVERY OF FIELD CONTROL INSTRUMENTATION SPARES FOR KUSILE POWER STATION ON AN AS AN WHEN REQUIRED BASIS FOR A PERIOD OF THREE (3) YEARS.

The following are questions and answers that have been made to tender enquiry MPKUS10324GX

| Questions | Answers |
|--|---|
| <p>1. OEM KUKLA</p> <p>Provide 4 digits serial number of the dosing electronics</p> | <p>0701998</p> <p>DOSING IS NOT APPLICABLE: DWC-5C/0000. ONLY WEIGHNG SIGNALS ARE REQUIRED COMPUTER: TYPE: WEIGHING; APPLICATION: WEIGH-FEEDER; SUPPL P/N: DWC-5C/0000; DISPLAY: LCD BACKGROUND LIT WITH 112X128 DOTS; KEYBOARD: AND PIECES FOIL KEYS WITH MULTIPLEXING; CONTROL INPUTS: 4 INPUTS WITH GALVANIC ISOLATION; CONTROL INPUT VOLTAGE: 12-28VDC, INTERRUPTION INPUTS: 2 X 12-28VDC GALVANIC ISOLATION; BCD DATA INPUTS: 2 X 4 DIGIT; 4 DATA LINES; 4 SCAN LINES; MAXIMUM CABLE LENGTH: 300M, CONTROL OUTPUTS: 6 X RELAY OUTPUTS, COUNTING PULSE OUTPUT: POTENTIAL FREE LOAD CELL SUPPLY: 10VDC WITH SENSE-INPUT FOR 5 CONDUCTOR WIRING, WEIGHING SIGNAL: 24 BIT A/D-CONVERTER, ANALOG INPUTS: 2 X 16-BIT A/D-CONVETER; ANALOG OUTPUT: 8-BIT D/A-CONVETER ON I/O CARD 1, 10 BIT D/A-CONVERTER ON I/O CARD 2, INTERFACE: RS232 AND PROFIBUS-DP, SUPPLY VOLTAGE: 220VAC.</p> |
| <p>2. OEM – SUCO</p> <p>The part number 0183 46 2 45 9 061 has a bar range of 100 – 300 bar and not 0 – 100 bar as mentioned. What is required</p> | <p>0648465</p> <p>Pressure range 100 to 300 bar (+/- 10)</p> <p>Pressure range correct.</p> |

| | |
|--|--|
| | SWITCH, PRESSURE: TYPE: HYDRAULIC/PNEUMATIC; RANGE: 0-100 BAR; POTENTIAL: 250 V; CURRENT: 5 A; ACTION: SPDT; CONNECTION: SCREW; CONTACT ARRANGEMENT: 1NC 1NO; POWER: 30-120 W; APPLICATION: BALL MILL SPEED REDUCER KV; ENCLOSURE RATING: IP65; SUPPL P/N: 0183-46245-9-061. |
| 3. Sick item 0643887 | Please do not quote this line item |
| 4. Kindly provide us with the full SICK part description or alternatively the 7 digit part number in order for us to assist. | 0645190 CORRECT PART NUMBER: NJ2-12GK-N. PEPPERL FUCHS PROXY SENSOR: TYPE: INDUCTIVE; SUPPL P/N: NJ2-12GK-N |
| 5. OEM FUJI ELECTRIC The part number for item 0648308 does not make sense?? It is the same as item 0647814 ? I can offer 0647814. But please verify item 0648308 | 0648308: SENSOR:OXYGEN;0-20 PCT;SPEC ZFK7 |
| 6. EOM FUJI ELETRIC The part number for item 0648308 does not make sense?? It is the same as item 0647814 ? I can offer 0647814. But please verify item 0648308 | 0647814: SENSOR:OXYGEN;0-20 PCT;SPEC ZFK8 SPECIFICATION: ZFK7 SPECIFICATION: ZFK8 |
| 7. OEM IFM The part number for item 0648308 does not make sense?? It is the same as item 0647814? I can offer 0647814. But please verify item 0648308 | 0648247 IFM Product. They'll advise of the replacement part number from: IG-2008 |
| 8. 643888 Sick item | Please do not quote this line item |
| 9. Sick Item 641846 | Please do not quote this line item |

Yours Faithfully

Romeo Mokwena
Procurement Representative