

ESKOM SAP NUMBER: 229921 ESKOM D-DT-3055 REV 23 & D-DT-1045 REV 1  
PRODUCT DESCRIPTION: BOX, POLE TOP SMART SPLIT METER, 8-WAY, 20A

ESKOM ENQUIRY NUMBER:			
PRODUCT MANUFACTURER:		PRODUCT CODE:	
TENDERER NAME:		TENDERER REPRESENTATIVE:	
TENDERER SIGNATURE:		DATE:	

Schedule B: Guarantees and technical particulars of equipment offered by the tenderer

Item	Sub-clause of 240-7569760	Description	Schedule A	Schedule B
1		<b>Identification</b>		
		1) Name of manufacturer	XXXXXXXXXXXXXX	_____
		2) Product code for the equipment	XXXXXXXXXXXXXX	_____
	3	<b>Requirements</b>		
2	3.1	<b>Climatic conditions</b>		
		1) Ambient air temperature °C	15 to 45	_____
		2) Average daily mean ambient air temperature °C	25	_____
		3) Altitude m	up to 1 800	_____
		4) Lightning conditions	Severe	_____
		5) Atmospheric: i) Coastal: Average humidity %	95	_____
		ii) Inland: Dry and dusty	Yes	_____
		6) Mean annual solar radiation W/m <sup>2</sup>	1000	_____
		7) Average annual rainfall mm	1000	_____
3	3.1.1:	<b>Service Distribution Box Types</b>		
		1) Split type 8-way for two phases. It shall be fitted with <b>four</b> MCBs with 5kA short circuit breaking capacity, DIN rails to accommodate eight smart split meters and connection points for 8 customers and a streetlight	Yes	_____
		2) Minimum dimensions as per D-DT-1045	Yes	_____

**TECHNICAL EVALUATION CRITERIA FOR  
SMART SPLIT METER POLE TOP BOXES FOR  
CENTRALEAST CLUSTER**
Unique Identifier: **KZN22SGTC01-AB7**Revision: **1**
**Technical A&B schedule (Item 7: SAP 229921)**

ESKOM SAP NUMBER: 229921

ESKOM D-DT-3055 REV 23 &amp; D-DT-1045 REV 1

PRODUCT DESCRIPTION: BOX, POLE TOP SMART SPLIT METER, 8-WAY, 20A

Item	Sub-clause of 240-7569760	Description	Schedule A	Schedule B
4	3.1.2	3) Height (min) mm	500	
		4) Width (min) mm	360	
		5) Depth (min) mm	150	
		<b>Box requirements:</b>		
		1) Do the boxes comply with clause 3.1.2 a)	Yes	
		2) Degree of protection of box shall be	IP 33 or better	
		3) Do the boxes comply with clause 3.1.2 c)	Yes	
		4) Do the boxes comply with clause 3.1.2 d)	Yes	
5	3.1.2.1:	<b>Material</b>		
		1) The box material	XXXXXXXXXXXXX	
		2) The box lid or door material (if different)	XXXXXXXXXXXXX	
		3) Are the materials used in the product as per NRS 032	Yes	
		4) The product shall be UV protected	Yes	
		5) The colour of the product shall be as per NRS 032	Yes	
6	3.1.3: 3.1.3.1	<b>Electrical equipment requirements:</b>		
		<b>Miniature circuit breakers</b>		
		1) MCB manufacturer	XXXXXXXXXXXXX	
		2) 40A hydraulic magnetic [Curve 1] or 50A thermal magnetic [Special Curve D]	XXXXXXXXXXXXX	
		3) DIN rail mounted	Yes	
		4) 5kA short circuit breaking capacity	Yes	
		5) 230V rated voltage	Yes	
		6) Compliance with SANS 556-1	Yes	

**TECHNICAL EVALUATION CRITERIA FOR  
SMART SPLIT METER POLE TOP BOXES FOR  
CENTRALEAST CLUSTER**
Unique Identifier: **KZN22SGTC01-AB7**Revision: **1**
**Technical A&B schedule (Item 7: SAP 229921)**

ESKOM SAP NUMBER: 229921

ESKOM D-DT-3055 REV 23 &amp; D-DT-1045 REV 1

PRODUCT DESCRIPTION: BOX, POLE TOP SMART SPLIT METER, 8-WAY, 20A

Item	Sub-clause of 240-7569760	Description	Schedule A	Schedule B
7	3.1.3.2	7) Discrimination with 20A standard curve MCB to 1kA	Yes	
		8) Tripping curve which conforms to limits in Annex A	Yes	
		<b>Busbars</b>		
		1) Busbar manufacturer	xxxxxxxxxxxxx	
		2) Do the busbars comply with clause 3.1.3.2 a)	Yes	
8	3.1.3.3	3) Do the busbars comply with clause 3.1.3.2 b)	Yes	
		4) Do the busbars comply with clause 3.1.3.2 c)	Yes	
		<b>Surge Arresters</b>		
		1) Surge arrester manufacturer	xxxxxxxxxxxxx	
		2) Do the surge arresters comply with clause 3.1.3.3 a)	Yes	
9	3.1.3.4	3) Do the surge arresters comply with clause 3.1.3.3 b)	Yes	
		<b>Power Supply Cables</b>		
		1) Power supply cables manufacturer	xxxxxxxxxxxxx	
		2) Do power supply cables comply with clause 3.1.3.4 a)	Yes	
		3) Do power supply cables comply with clause 3.1.3.4 b)	Yes	
10	3.1.3.5	<b>Internal Wiring</b>		
		1) Internal wires manufacturer	xxxxxxxxxxxxx	
		2) Does the internal wiring comply with clause 3.1.3.5 a)	Yes	
		3) Does the internal wiring comply with clause 3.1.3.5 b)	Yes	
		4) Does the internal wiring comply with clause 3.1.3.5 c)	Yes	
		5) Does the internal wiring comply with clause 3.1.3.5 d)	Yes	

**TECHNICAL EVALUATION CRITERIA FOR  
SMART SPLIT METER POLE TOP BOXES FOR  
CENTRALEAST CLUSTER**
Unique Identifier: **KZN22SGTC01-AB7**Revision: **1**
**Technical A&B schedule (Item 7: SAP 229921)**

ESKOM SAP NUMBER: 229921

ESKOM D-DT-3055 REV 23 &amp; D-DT-1045 REV 1

PRODUCT DESCRIPTION: BOX, POLE TOP SMART SPLIT METER, 8-WAY, 20A

Item	Sub-clause of 240-7569760	Description	Schedule A	Schedule B
11	3.1.3.6	<b>Cable Glands</b>		
		1) Cable glands manufacturer	xxxxxxxxxxxxxx	
		2) Does the cable glands comply with clause 3.1.3.6 a)	Yes	
12	3.1.3.7	3) Are all the cable entries, holes and cable glands sealed or plugged with a stopper to mitigate ingress of dust, insects, and vermin	Yes	
		<b>Split Meters</b>		
13	3.3	1) Does the product comply with clause 3.1.3.7 a)	Yes	
		<b>Marking, Labelling &amp; Packaging</b>		
		1) Are the products indelibly marked	Yes	
		2) Was evidence of the product markings submitted, plainly showing the details of the products markings	Yes	
		3) Does the product comply with clause 3.3 a)	Yes	
		4) Does the product comply with clause 3.3 b)	Yes	
		5) Does the product comply with clause 3.3 c)	Yes	
		6) Does the product comply with clause 3.3 d)	Yes	
		7) Does the product comply with clause 3.3 e)	Yes	
		8) Does the packaging protect and does not damage the product during normal handling, transport & storage	Yes	
		9) Does the packaging permit identification of the items	Yes	
		10) Was evidence of the product packaging submitted plainly showing the details of the products packaging	Yes	
		11) Are product or installation instructions provided	xxxxxxxxxxxxxx	