




CLARIFICATION/RESPONSES

Date: 29.07.2022
Ref: KZN028 - 2
Enquiries: Thabile Sibiya
Tel: 031 710 5396
Email: sibiyaTh@eskom.co.za

Description	Response
<p>Clarify the wiring in the boxes as the usual ESKOM spec and the drawing that was submitted on the Tender Bulletin is contradicting each other. – see attached.</p> <p>Which dimension for the Outgoing and Ingoing tails should be used for this Job?</p> <p>ESKOM Spec says 25mm but the drawing refers to 16mm and 10mm –</p> <p>This will affect the pricing.</p> <div style="display: flex; justify-content: space-around; align-items: flex-end;"> <div style="text-align: center;">  2 4 8 Pole ESKOM spec.pdf </div> <div style="text-align: center;">  1042 Rev1.pdf </div> <div style="text-align: center;">  1043 Rev1.pdf </div> </div>	<p>Eskom standard 240-75659760 details the requirements for the supply of pole mounted service distribution boxes used for smart split meter applications. The power supply cable and internal wiring requirements are detailed in clause 3.1.3.4 & 3.1.3.5 of Eskom standard 240-75659760.</p> <p>The power supply cables and conductor used for the internal wiring are dissimilar.</p> <p>Should there be any deviations from the technical requirements these should be stated on the product technical deviation sheet(s) clearly indicating the proposed deviation and the reason(s) thereof for Eskom technical consideration.</p>
<p>We just want to confirm the quantities of supply of pole top boxes on tender no: KZN028</p>	<p>Refer to the NEC Supply Contract</p>