



SPEC SHEET

SAP MATERIAL No.:	0168611							
SHORT DESCRIPTION:	KIOSK METER:1PH ;16 KVA ;EMPTY							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; EMPTY METER KIOSK FOR SINGLE PHASE SMALL POWER USERS ; FITTED WITH DIN RAIL AND EARTH STUD; INDELIBLE MFNRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1004; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0168866							
SHORT DESCRIPTION:	KIOSK METER:1PH ;10 KVA ;SPU							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 10 KVA; TYPE: SPU; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 10KVA SMALL POWER USERS; FULLY FITTED WITH ONE APPROVED 80A SINGLE PHASE METER SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 40A SINGLE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1004; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1004; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0168580							
SHORT DESCRIPTION:	KIOSK METER:1PH;16 KVA;SPU							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: SPU; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 16KVA SMALL POWER USERS; FULLY FITTED WITH ONE APPROVED 80A SINGLE PHASE METER SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A SINGLE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED LIVE PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-DT-1004; INDELIBLE MFNRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1004; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
ITEM	:- KIOSK METER 10/16kVA 1 PH SPU							
MATERIAL SPECIFICATION	:-							
CORROSION SPECIFICATION	:- 240-98195962							
STANDARD SPECIFICATION	:-							
ESKOM SPECIFICATION	:- 240-76628293, D-DT-1004							
TEST & CERTIFICATION REQUIREMENTS :-								
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004			SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004			0168611		0168580
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004			0168866		
				D-DT-3236		SET	SHEET	REV
						34	1	14

Unique Identifier:240-48887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:	0168612						
SHORT DESCRIPTION:	KIOSK METER:3PH;25 KVA;EMPTY						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25 KVA; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; EMPTY KIOSK FOR 25 AND 50 KVA SMALL POWER USERS; FITTED WITH INNER PLATE, DIN RAIL AND EARTH STUD; INDELIBLE MFNRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1002; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0168867						
SHORT DESCRIPTION:	KIOSK METER:3PH ;25 KVA ;SPU						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25 KVA; TYPE: SPU; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 25KVA SMALL POWER USERS; FULLY FITTED WITH ONE APPROVED THREE PHASE 100A METER; SEALED AND CALIBRATED WITH CALIBRATION CERTIFICATE STICKER AFFIXED ON METER; 40 AMP THREE POLE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED LIVE PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER, D-1002; INDELIBLE MFNRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1002; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0168758						
SHORT DESCRIPTION:	KIOSK METER:3PH ;50 KVA ;SPU						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 50 KVA; TYPE: SPU; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 50KVA SMALL POWER USERS; FULLY FITTED WITH ONE APPROVED 100A THREE PHASE METER SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A THREE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED LIVE PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1002; INDELIBLE MFNRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1002; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
ITEM :- KIOSK METER 3 PH SPU							
MATERIAL SPECIFICATION :-							
CORROSION SPECIFICATION :- 240-98195962							
STANDARD SPECIFICATION :-							
ESKOM SPECIFICATION :- 240-76628293, D-DT-1002, D-DT-1003,							
TEST & CERTIFICATION REQUIREMENTS :-							
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS		0168612	
				CAD REF:		0168867	
				SERIES 3000		0168758	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		SET	SHEET
				3236		34	2
				 D-DT-3236		14	

Unique Identifier:240-4887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:		0182382							
SHORT DESCRIPTION:		KIOSK METER:3PH ;25 KVA ;RURAFLEX							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25 KVA; TYPE: RURAFLEX; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; SPECIFICATION: ESKOM: 240-76628293; FOR 25KVA SMALL POWER USER RURAFLEX TARIFF; FULLY FITTED WITH 40A THREE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1002; WITHOUT METER; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D3236; MNFR DRG: D-1002; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0182383							
SHORT DESCRIPTION:		KIOSK METER:3PH ;50 KVA ;RURA FLEX							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 50 KVA; TYPE: RURA FLEX; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY-C35 SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 50KVA SMALL POWER USER RURAFLEX TARIFF; FULLY FITTED WITH 80A THREE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1002; WITHOUT METER; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1002; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0206261							
SHORT DESCRIPTION:		KIOSK METER:3PH ;25-50 KVA ;PREPAY							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25-50 KVA; TYPE: PREPAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 25 AND 50KVA PREPAYMENT CUSTOMERS; FULLY FITTED WITH 80A THREE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1002; WITHOUT METER; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1002; MNFR DRG: D-1015; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE	 D-DT-3236		SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:			0182382		0206261
				SERIES 3000			SET	SHEET	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:			34	3	14
				3236					

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0212966							
SHORT DESCRIPTION:	KIOSK METER:3PH ;25-50 KVA ;BASE							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25-50 KVA; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1002; FOR USE WITH STANDARD 25/50KVA METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS								
SAP MATERIAL No.:	0168335							
SHORT DESCRIPTION:	KIOSK METER:3PH ;100 KVA ;SPU							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 100 KVA; TYPE: SPU; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; FOR 100KVA SMALL POWER USERS; FULLY FITTED WITH ONE APPROVED 160A THREE PHASE METER SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 150A THREE POLE MOULDED CASE CIRCUIT BREAKER WITH COVER NO EXPOSED PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1003; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1003; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0649125							
SHORT DESCRIPTION:	KIOSK METER:3PH;100 KVA;EMPTY							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 100 KVA; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; EMPTY METER KIOSK FOR 100KVA SMALL AND LARGE POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1003; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0631924							
SHORT DESCRIPTION:	KIOSK METER:3PH ;100 KVA ;BASE							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 100 KVA; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1003; FOR USE WITH STANDARD 100KVA METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021	
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	HPD GROENEWALD	DATE:	01.08.2004			SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004			0168335 0649125		
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004			0212966 0631924		
				D-DT-3236		SET SHEET REV		
						34 4 14		

SPEC SHEET

SAP MATERIAL No.:	0168584
SHORT DESCRIPTION:	BOX,METER EMPTY ECU/ED WALL MTN. D3236

TECH. DESCRIPTION:

EMPTY METER BOX ENCLOSURE TO HOUSE ED/ECU AND STANDARD BASE *

DIMENSIONS INDICATED ARE INSIDE DIMENSIONS *

MANUFACTURED FROM UV STABLE DOUGH MOULDED COMPOUND (DMC)/3CR12/UV STABLE THERMO PLASTIC *

3CR12 PICKLED AND PASSIVATED *

CAPTIVE FRONT LID SHALL SLIDE UPWARDS TO OPEN *

WATERPROOF * IP RATING 54 *

DMC BOXES TO HAVE 3 MOULDED BOSSES WITH BRASS M6 SCREW THREAD INSERTS, SUITABLE FOR M6 x 10mm MACHINE SCREWS *

3CR12 BOXES TO HAVE 3 SPOT WELDED BOSSES WITH M6 THREAD, SUITABLE FOR M6 x 10mm MACHINE SCREWS *

BOSSES USED TO MOUNT STANDARD PASSIVE BASE ARE POSITIONED AS INDICATED ON DETAIL DRAWING *

BOX SUPPLIED WITH A CORROSION RESISTANT M6 x 10mm MACHINE SCREW IN EACH BOSS *

METER BOX MOUNTING BRACKET TO BE THICK ENOUGH TO PROVIDE ADEQUATE STRENGTH *

THERE SHALL BE NO HOLES THROUGH THE BOX OTHER THAN THE GLAND HOLES *

HOLES FOR TWO No. 1 GLANDS AT BASE *

SUPPLIED WITH WALL MOUNTING BRACKETS (20x2mm THICK GALVANISED MILD STEEL/3CR12) AS SHOWN ON SHEET 1 *

SUPPLIED WITH THE LOCKING MECHANISM AS SHOWN ON SHEET 3 *

BOLT STOP TO BE MANUFACTURED FROM STAINLESS STEEL *

ESKOM DRAWING No. D-DT-3236 *

(ALL INFORMATION TAKEN FROM D-DT-3013)

ITEM		:-		KIOSK METER 10/16kVA 1 PH SPU			
MATERIAL SPECIFICATION		:-					
CORROSION SPECIFICATION		:-		240-98195962			
STANDARD SPECIFICATION		:-					
ESKOM SPECIFICATION		:-		DSP 34-871, D-DT-1004, DSP 34-1068, DSP 34-875, DST 34-749			
TEST & CERTIFICATION REQUIREMENTS		:-					
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	<div> Eskom</div> <div>D-DT-3236</div>		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004			0168584	
						SET	SHEET
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004			34	5
						14	

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0185731
SHORT DESCRIPTION:	BOX,METER EMPTY ECU/ED POLE MTN. D3236

TECH. DESCRIPTION:

EMPTY METER BOX ENCLOSURE TO HOUSE ED/ECU AND STANDARD BASE *

DIMENSIONS INDICATED ARE INSIDE DIMENSIONS *

MANUFACTURED FROM UV STABLE DOUGH MOULDED COMPOUND (DMC)/3CR12/UV STABLE THERMO PLASTIC *

3CR12 PICKLED AND PASSIVATED *

CAPTIVE FRONT LID SHALL SLIDE UPWARDS TO OPEN *

WATERPROOF * IP RATING 54 *

DMC BOXES TO HAVE 3 MOULDED BOSSES WITH BRASS M6 SCREW THREAD INSERTS, SUITABLE FOR M6 x 10mm MACHINE SCREWS *

3CR12 BOXES TO HAVE 3 SPOT WELDED BOSSES WITH M6 THREAD, SUITABLE FOR M6 x 10mm MACHINE SCREWS *

BOSSES USED TO MOUNT STANDARD PASSIVE BASE ARE POSITIONED AS INDICATED ON DETAIL DRAWING *

BOX SUPPLIED WITH A CORROSION RESISTANT M6 x 10mm MACHINE SCREW IN EACH BOSS *

METER BOX MOUNTING BRACKET TO BE THICK ENOUGH TO PROVIDE ADEQUATE STRENGTH *

THERE SHALL BE NO HOLES THROUGH THE BOX OTHER THAN THE GLAND HOLES * HOLES FOR TWO No. 1 GLANDS AT BASE *


SUPPLIED WITH POLE MOUNTING BRACKETS (20 x 2mm THICK GALVANISED MILD STEEL/3CR12) FOR USE WITH 12mm BANDIT STRAP (SEE D DT 3131). BRACKET SHALL FIT ONTO M6 BOSSES AS SHOWN ON SHEET 2 *

SUPPLIED WITH THE LOCKING MECHANISM AS SHOWN ON SHEET 3 *

BOLT STOP TO BE MANUFACTURED FROM STAINLESS STEEL *

ESKOM DRAWING No. D-DT-3236 *

(ALL INFORMATION TAKEN FROM D-DT-3013)

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021			
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019			
REV	REVISION DESCRIPTION			BY	CHKD	AUTH		DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE NTS	 D-DT-3236		SAP No:			
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF: SERIES 3000			0185731			
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No: 3236			SET	SHEET	REV	
						34	6	14		

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0186798
SHORT DESCRIPTION:	KIOSK METER:1PH :16 KVA :2 WAY : BS METERS

TECH. DESCRIPTION:

KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 2 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 2-WAY 16KVA SMALL POWER USERS; FULLY FITTED WITH TWO APPROVED BS FOOTPRINT 80A SINGLE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1011; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1011; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).


REVISION NUMBER (If any, Else 0001):	
SAP MATERIAL No.:	0214975
SHORT DESCRIPTION:	KIOSK METER:1PH :16 KVA :3 WAY : BS METERS

TECH. DESCRIPTION:

KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 3 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 3 WAY 16KVA SMALL POWER USERS; FULLY FITTED WITH THREE APPROVED BS FOOTPRINT 80A SINGLE PHASE METERS; SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS; CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1011; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1011; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).

ITEM		:- KIOSK METER MULTIWAY 1 PH SPU															
MATERIAL SPECIFICATION		:-															
CORROSION SPECIFICATION		:- 240-98195962															
STANDARD SPECIFICATION		:-															
ESKOM SPECIFICATION		:- 240-76625427, D-DT-1011, 1019, 1020, 1022,															
TEST & CERTIFICATION REQUIREMENTS :-																	
INSPECTION		Yes		No		ESKOM RELEASE NOTE				Yes		No					
IDENTIFICATION:- INDELIBILE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS																	
14		SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.				JS		HPD GROENEWALD		HPD GROENEWALD		18.08.2021					
13		0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420				P.A.T.		HPD GROENEWALD		HPD GROENEWALD		03.05.2019					
REV		REVISION DESCRIPTION				BY		CHKD		AUTH		DATE		REF. DWGS			
AUTH:		HPD GROENEWALD		DATE: 01.08.2004		SCALE		<div> Eskom</div> <div>D-DT-3236</div>				SAP No:					
						NTS						0186798					
CHKD:		HPD GROENEWALD		DATE: 01.07.2004		CAD REF:						0214975					
						SERIES 3000						SET		SHEET		REV	
DRAWN:		P.A. VERMAAK		DATE: 01.07.2004		FILE No: 3236						34		7		14	

SPEC SHEET

SAP MATERIAL No.:		0212967							
SHORT DESCRIPTION:		KIOSK METER:1PH ;16 KVA ;4 WAY ; BS METERS							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 4 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 4 WAY 16KVA SMALL POWER USERS; FULLY FITTED WITH FOUR APPROVED BS FOOTPRINT 80A SINGLE PHASE METERS; SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS; CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1019; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1019; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0212968							
SHORT DESCRIPTION:		KIOSK METER:1PH ;16 KVA ;6 WAY ; BS METERS							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 6 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 6 WAY 16KVA SMALL POWER USERS; FULLY FITTED WITH SIX APPROVED BS FOOTPRINT 80A SINGLE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1020; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1020; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0223630							
SHORT DESCRIPTION:		KIOSK METER:1PH ;16 KVA ;15 WAY							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 15 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625577; FOR 15 WAY 16KVA SMALL POWER USERS; FULLY FITTED WITH FIFTEEN APPROVED BS FOOTPRINT 80A SINGLE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1022; MOULDED CASE CIRCUIT BREAKER SIZE AS REQUIRED; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1022; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021			
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019			
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE NTS	 D-DT-3236		SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:			0212967		0223630
				SERIES 3000			0212968		
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:			SET	SHEET	REV
				3236			34	8	14

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:		0212969	
SHORT DESCRIPTION:		KIOSK METER:1PH ;2 WAY ;EMPTY ; BS METERS	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 2 WAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 2 AND 3 WAY SMALL POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD AND BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1011; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0212970	
SHORT DESCRIPTION:		KIOSK METER:1PH ;4 WAY ;EMPTY ; BS METERS	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4 WAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 4 WAY SMALL POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD AND BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1019; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0212971	
SHORT DESCRIPTION:		KIOSK METER:1PH ;6 WAY ;EMPTY ; BS METERS	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 6 WAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 6 WAY SMALL POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD AND BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1020; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			


Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0214976
SHORT DESCRIPTION:	KIOSK METER:1PH ;MULTIWAY ;BASE
TECH. DESCRIPTION:	
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: MULTIWAY; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1011 SHEET 6; FOR USE WITH STANDARD 2, 3, 4, 6 MULTI-WAY METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: D-3236; MNFR DRG: D-1011; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	


SAP MATERIAL No.:	0214977
SHORT DESCRIPTION:	KIOSK METER:1PH ;MULTI ;TAPERED BASE
TECH. DESCRIPTION:	
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: MULTI; TYPE: TAPERED BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1011 SHEET 5; FOR USE WITH STANDARD 2, 3, 4, 6 MULTI-WAY METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).; DRAWING NO: D-3236; MNFR DRG: D-1011 SHT 5; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021	
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:		
				NTS		0214976		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:		0214977		
				SERIES 3000	D-DT-3236	SET	SHEET	REV
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		34	10	14
				3236				

Unique Identifier:240-4887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:	0186799							
SHORT DESCRIPTION:	KIOSK METER:3PH ;25 KVA ;2 WAY							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25 KVA; TYPE: 2 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 2 WAY 25KVA SMALL POWER USERS; FULLY FITTED WITH TWO APPROVED 100A THREE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 40A THREE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1012; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1012; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0212972							
SHORT DESCRIPTION:	KIOSK METER:3PH ;50 KVA ;2 WAY							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 50 KVA; TYPE: 2 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 2 WAY 50KVA SMALL POWER USERS; FULLY FITTED WITH TWO APPROVED 100A THREE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A THREE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1012; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1012; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0212974							
SHORT DESCRIPTION:	KIOSK METER:3PH ;2 WAY ;EMPTY							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 2 WAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 2 WAY THREE PHASE SMALL POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD AND BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1012; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
ITEM	:- KIOSK METER MULTIWAY 3 PH SPU							
MATERIAL SPECIFICATION	:-							
CORROSION SPECIFICATION	:- 240-98195962							
STANDARD SPECIFICATION	:-							
ESKOM SPECIFICATION	:- 240-76625427, D-DT-1012, 1018,							
TEST & CERTIFICATION REQUIREMENTS :-								
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004			SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004			0186799		0212974
RAWN:	P.A. VERMAAK	DATE:	01.07.2004			0212972		
				D-DT-3236		SET	SHEET	REV
						34	11	14

Unique Identifier:240-48887441


Revision 1

SPEC SHEET


SAP MATERIAL No.:		0214137								
SHORT DESCRIPTION:		KIOSK METER:3PH ;25 KVA ;4 WAY								
TECH. DESCRIPTION:										
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 25 KVA; TYPE: 4 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 4 WAY 25KVA SMALL POWER USERS; FULLY FITTED WITH FOUR APPROVED 100A THREE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 40A THREE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1018; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1018; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
SAP MATERIAL No.:		0212973								
SHORT DESCRIPTION:		KIOSK METER:3PH ;50 KVA ;4 WAY								
TECH. DESCRIPTION:										
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 50 KVA; TYPE: 4 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 4 WAY 50KVA SMALL POWER USERS; FULLY FITTED WITH FOUR APPROVED 100A THREE PHASE METERS SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 80A THREE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE); BUSBARS, WIRING AND TERMINALS AS PER D-1018; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1018; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
SAP MATERIAL No.:		0212975								
SHORT DESCRIPTION:		KIOSK METER:3PH ;4 WAY ;EMPTY								
TECH. DESCRIPTION:										
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 4 WAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 4 WAY THREE PHASE SMALL POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD AND BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1018; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
SAP MATERIAL No.:		0688001								
SHORT DESCRIPTION:		KSK MTR:3PH;50 KVA;4 WAY NO BASE								
TECH. DESCRIPTION:										
KIOSK METER: PHASE: 3PH; SUPPLY: 0 KVA; TYPE: DC SECURE POLE MOUNT; MATERIAL: 3CR12 POWDER COATED; COLOR: GRAY LIGHT NAVY - C35 SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT DATA CONCENTRATOR (DC) KIOSK ; FULLY FITTED WITH FOUR 10A 5KA SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING AS PER D-1034; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1034; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021				
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019				
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS		
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE				SAP No:		
				NTS						
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:				0214137		
				SERIES 3000			0212973	0688001		
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		D-DT-3236		SET	SHEET	REV
				3236				34	12	14

SPEC SHEET

SAP MATERIAL No.:		0214978	
SHORT DESCRIPTION:		KIOSK METER:3PH ;2 WAY ;BASE	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 2 WAY; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1012 SHEET 6; FOR USE WITH STANDARD 2 WAY THREE PHASE METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: D-3236; MNFR DRG: D-1012; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0214979	
SHORT DESCRIPTION:		KIOSK METER:3PH ;4 WAY ;BASE	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 4 WAY; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1018 SHEET 6; FOR USE WITH STANDARD 4 WAY THREE PHASE METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: D-3236; MNFR DRG: D-1018; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0214980	
SHORT DESCRIPTION:		KIOSK METER:3PH ;2 WAY ;TAPERED BASE	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 2 WAY; TYPE: TAPERED BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK BASE TAPERED; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1012 SHEET 5; FOR USE WITH STANDARD 2 WAY THREE PHASE METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: D-3236; MNFR DRG: D-1012; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0214991	
SHORT DESCRIPTION:		KIOSK METER:3PH ;4 WAY ;TAPERED BASE	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 4 WAY; TYPE: TAPERED BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY -C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK BASE TAPERED; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1018 SHEET 5; FOR USE WITH STANDARD 4 WAY THREE PHASE METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1018; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021				
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019				
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS		
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE				SAP No:		
				NTS				0214978		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:				0214979		
				SERIES 3000				0214991		
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		D-DT-3236		SET	SHEET	REV
				3236				34	13	14

SPEC SHEET

SAP MATERIAL No.:	0168599						
SHORT DESCRIPTION:	KIOSK METER:3PH ;200 KVA ;EMPTY PM						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 200 KVA; TYPE: EMPTY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628117; POLE MOUNT; EMPTY METER KIOSK FOR 200-500KVA THREE PHASE LARGE POWER USERS; FITTED WITH INNER PLATE, DIN RAILS, NEUTRAL AND EARTH BUSBARS AND BUSBAR INSULATORS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1000; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0168733						
SHORT DESCRIPTION:	KIOSK METER:3PH ;200 KVA ;BASE						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 200 KVA; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628117; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1000; FOR USE WITH STANDARD 200-500KVA THREE PHASE METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: D-3236; MNFR DRG: D-1000; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0168620						
SHORT DESCRIPTION:	KIOSK METER:3PH ;100 KVA ;LPU PM						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 100 KVA; TYPE: LPU PM; MATERIAL: 3CR12; POWDER COATED; COLOR: NAVY LIGHT GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628293; POLE MOUNTED; FOR 100KVA LARGE POWER USERS; FULLY FITTED WITH ONE APPROVED 160A THREE PHASE PROGRAMMABLE METER SEALED; CALIBRATED WITH CALIBRATION STICKER AFFIXED ON METER; 150A THREE POLE MOULDED CASE CIRCUIT BREAKER WITH COVER NO EXPOSED PARTS (TOUCH SAFE); WIRING AND TERMINALS AS PER D-1003; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1003; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
ITEM :- KIOSK METER 100 - 500kVA LPU							
MATERIAL SPECIFICATION :-							
CORROSION SPECIFICATION :- 240-98195962							
STANDARD SPECIFICATION :-							
ESKOM SPECIFICATION :- 240-76628117, D-DT-1000,							
TEST & CERTIFICATION REQUIREMENTS :-							
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS		0168599	
				CAD REF:		0168733	
				SERIES 3000		0168620	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		SET	SHEET
				3236		34	14
				 D-DT-3236			14

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:		0168623	
SHORT DESCRIPTION:		KIOSK METER:3PH ;200 KVA ;LPU PM	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 200 KVA; TYPE: LPU PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628117; POLE/GROUND MOUNT FOR 200KVA LARGE POWER USERS; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1000; EXCLUDING METER; INCLUDING 300A THREE POLE MOULDED CASE CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (300-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D3236; MNFR DRG: D-1000; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0168624	
SHORT DESCRIPTION:		KIOSK METER:3PH ;315 KVA ;LPU PM	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 315 KVA; TYPE: LPU PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628117; POLE/GROUND MOUNT FOR 315KVA LARGE POWER USERS; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1000; EXCLUDING METER; INCLUDING 450A THREE POLE MOULDED CASE CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (500-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1000; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0168626	
SHORT DESCRIPTION:		KIOSK METER:3PH ;500 KVA ;LPU PM	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 500 KVA; TYPE: LPU PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628117; POLE/GROUND MOUNT FOR 500KVA LARGE POWER USERS; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1000; EXCLUDING METER; INCLUDING 800A THREE POLE MOULDED CASE CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (800-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1000; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.	JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420	P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE	SAP No: 0168623 0168624		
				NTS			
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:	D-DT-3236		
				SERIES 3000			
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:	34 15 14		
				3236			

Eskom

D-DT-3236

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0168600						
SHORT DESCRIPTION:	KIOSK METER:3PH ;CT/VT ; EMPTY						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: EMPTY POLE MOUNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628667; EMPTY METER KIOSK FOR CT/VT UNIT THREE PHASE LARGE POWER USERS; FITTED WITH INNER PLATE, DIN RAILS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1001; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0168732						
SHORT DESCRIPTION:	KIOSK METER:3PH ;CT/VT ;BASE						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628667; METER KIOSK BASE; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-1001; FOR USE WITH STANDARD CT/VT UNIT THREE PHASE METERING KIOSKS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: D-3236; MNFR DRG: D-1001; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0168627						
SHORT DESCRIPTION:	KIOSK METER:3PH ;CT/VT						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: 3P4W LPU POLE MOUNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628667; POLE/GROUND MOUNT FOR CT/VT UNIT LARGE POWER USERS; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1001; EXCLUDING METER; INCLUDING: FUSE HOLDERS AND FUSES, TEST BLOCKS, 110V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1001; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
ITEM :- KIOSK METER CT/VT UNIT LPU							
MATERIAL SPECIFICATION :-							
CORROSION SPECIFICATION :- 240-98195962							
STANDARD SPECIFICATION :-							
ESKOM SPECIFICATION :- 240-76628667, D-DT-1001							
TEST & CERTIFICATION REQUIREMENTS :-							
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS		0168600	
				CAD REF:		0168732	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	SERIES 3000		0168627	
				FILE No:		SET SHEET REV	
				3236		34 16 14	

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0194123
SHORT DESCRIPTION:	KIOSK METER:3PH :800 KVA :GROUND MOUNT

TECH. DESCRIPTION:

KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 800 KVA; TYPE: GROUND MOUNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628297; GROUND MOUNT FOR LARGE POWER USERS LOW VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1016; EXCLUDING METER; INCLUDING 1600A THREE POLE AIR CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (1600-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1016; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).


SAP MATERIAL No.:	0194124
SHORT DESCRIPTION:	KIOSK METER:3PH :1000 KVA :GROUND MOUNT

TECH DESCRIPTION:

KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 1000 KVA; TYPE: GROUND MOUNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628297; GROUND MOUNT FOR 1MVA LARGE POWER USERS LOW VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1016; EXCLUDING METER; INCLUDING 1600A THREE POLE AIR CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (1600-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1016; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).

ITEM		:- KIOSK METER 800 - 1000kVA LPU												
MATERIAL SPECIFICATION		:-												
CORROSION SPECIFICATION		:- 240-98195962												
STANDARD SPECIFICATION		:-												
ESKOM SPECIFICATION		:- 240-76628297, D-DT-1016												
TEST & CERTIFICATION REQUIREMENTS :-														
INSPECTION		Yes		No		ESKOM RELEASE NOTE				Yes		No		
IDENTIFICATION:- INDELIBILE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS														
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.					JS	HPD GROENEWALD		HPD GROENEWALD		18.08.2021			
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420					P.A.T.	HPD GROENEWALD		HPD GROENEWALD		03.05.2019			
REV	REVISION DESCRIPTION					BY	CHKD		AUTH		DATE		REF. DWGS	
AUTH:	HPD GROENEWALD		DATE:	01.08.2004		SCALE					SAP No:			
						NTS					0194123			
CHKD:	HPD GROENEWALD		DATE:	01.07.2004		CAD REF:					0194124			
						SERIES 3000					SET	SHEET	REV	
DRAWN:	P.A. VERMAAK		DATE:	01.07.2004		FILE No:	D-DT-3236				34	17	14	
						3236								

SPEC SHEET

SAP MATERIAL No.:	0212961						
SHORT DESCRIPTION:	KIOSK METER:3PH ;WALL MOUNT 400V						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: WALL MOUNT 400V; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628295; WALL MOUNT FOR SINGLE METERING POINT LARGE POWER USERS LOW VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1014; EXCLUDING METER; INCLUDING FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1014; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0212962						
SHORT DESCRIPTION:	KIOSK METER:3PH ;WALL MOUNT 110V						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: WALL MOUNT 110V; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628295; WALL MOUNTED FOR SINGLE METERING POINT LARGE POWER USERS MEDIUM VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1014; EXCLUDING METER; INCLUDING FUSE HOLDERS AND FUSES, TEST BLOCKS, 110V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1014; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0212963						
SHORT DESCRIPTION:	KIOSK METER:3PH ;WALL MOUNT ;400V PLATE						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: 400V PLATE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76628295; WALL MOUNTED METER PLATE FOR SINGLE METERING POINT LARGE POWER USERS LOW VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1021; EXCLUDING METER; INCLUDING FUSE HOLDERS AND FUSES; TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1021; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
ITEM :- KIOSK INDOOR WALL MOUNT							
MATERIAL SPECIFICATION :-							
CORROSION SPECIFICATION :- 240-98195962							
STANDARD SPECIFICATION :-							
ESKOM SPECIFICATION :- 240-76628295, D-DT-1014, 1021, 5801,							
TEST & CERTIFICATION REQUIREMENTS :-							
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS		0212961	
				CAD REF:		0212962	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	SERIES 3000		SET	
				FILE No:		SHEET	
				3236		REV	
				 D-DT-3236		34 18 14	

Unique Identifier:240-4887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0212964
SHORT DESCRIPTION:	KIOSK METER:3PH :WALL MOUNT :110V PLATE


TECH. DESCRIPTION:

KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: CT/VT; TYPE: 110V PLATE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628295; WALL MOUNT METER PLATE FOR SINGLE METERING POINT LARGE POWER USERS MEDIUM VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1021; EXCLUDING METER; INCLUDING FUSE HOLDERS AND FUSES, TEST BLOCKS, 110V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1021; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).

SAP MATERIAL No.:	0212965
SHORT DESCRIPTION:	KIOSK METER:3PH ;SUBS ;WALL MOUNT EMPTY

TECH. DESCRIPTION:

KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: SUBS; TYPE: WALL MOUNT EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY C35 TO SANS 1091; STANDARD: ESKOM: 240-76628295; EMPTY INDOOR WALL MOUNTED SUBSTATION METER PANEL TO D-5801; SUITABLE FOR THE FITMENT OF TWO METERING MODULES (D-5804); INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D3236; MNFR DRG: D-5801; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.				JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021				
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420				P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019				
REV	REVISION DESCRIPTION				BY	CHKD	AUTH		DATE	REF. DWGS		
AUTH:	HPD GROENEWALD		DATE:	01.08.2004	SCALE				SAP No:			
					NTS				0212964			
CHKD:	HPD GROENEWALD		DATE:	01.07.2004	CAD REF:				0212965			
					SERIES 3000		D-DT-3236		SET	SHEET	REV	
DRAWN:	P.A. VERMAAK		DATE:	01.07.2004	FILE No:				34	19	14	
					3236							

SPEC SHEET

[illegible]

Unique Identifier:240-48887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:		0223738					
SHORT DESCRIPTION:		KIOSK METER:3PH ;315 KVA ;GROUND MOUNT					
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 315 KVA; TYPE: GROUND MOUNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628297; FOR 315KVA LARGE POWER USERS LOW VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1023; EXCLUDING METER; INCLUDING 450A THREE POLE MOULDED CASE CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (500-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1023; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:		0223740					
SHORT DESCRIPTION:		KIOSK METER:3PH ;500 KVA ;GROUND MOUNT					
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: 500 KVA; TYPE: GROUND MOUNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76628297; FOR 500KVA LARGE POWER USERS LOW VOLTAGE; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-1023; EXCLUDING METER; INCLUDING 800A THREE POLE MOULDED CASE CIRCUIT BREAKER, BUSBARS, INSULATORS, CTS (800-5A), FUSE HOLDERS AND FUSES, TEST BLOCKS, 230V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1023; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							

Unique Identifier:240-48887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:	0569532							
SHORT DESCRIPTION:	KIOSK METER:1PH ;4.6 KVA ;4 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 4 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM:240-52840756; FOR SECURE GROUND MOUNT 4-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH FOUR 20A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1026; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1026; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
SAP MATERIAL No.:	0569533							
SHORT DESCRIPTION:	KIOSK METER:1PH ;4.6 KVA ;6 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 6 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM:240-52840756; FOR SECURE GROUND MOUNT 6-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH SIX 20A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1027; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1027; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
SAP MATERIAL No.:	0569534							
SHORT DESCRIPTION:	KIOSK METER:1PH ;4.6 KVA ;8 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 8 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 8-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH EIGHT 20A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1028; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1028; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
ITEM	:- KIOSK SECURE GROUND MOUNT							
MATERIAL SPECIFICATION	:-							
CORROSION SPECIFICATION	:- 240-98195962							
STANDARD SPECIFICATION	:-							
ESKOM SPECIFICATION	:- 240-52840756, D-DT-1026, 1027, 1028, 1029							
TEST & CERTIFICATION REQUIREMENTS :-								
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004			SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004			0569532		0569534
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004			0569533		
				D-DT-3236		SET	SHEET	REV
						34	22	14

Unique Identifier:240-48887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:		0569535							
SHORT DESCRIPTION:		KIOSK METER:1PH ;4.6 KVA ;12 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 12 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 12-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH TWELVE 20A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1029; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1029; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0569536							
SHORT DESCRIPTION:		KIOSK METER:1PH ;14 KVA ;4 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 4 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 4-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH FOUR 60A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1026; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1026; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0569537							
SHORT DESCRIPTION:		KIOSK METER:1PH ;14 KVA ;6 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 6 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 6-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH SIX 60A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1027; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D3236; MNFR DRG: D-1027; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021			
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019			
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE	 D-DT-3236		SAP No:		
				NTS			0569535		0569537
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:			0569536		
				SERIES 3000			SET	SHEET	REV
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:			34	23	14
				3236					

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0569538							
SHORT DESCRIPTION:	KIOSK METER:1PH ;14 KVA ;8 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION: KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 8 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 8-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH EIGHT 60A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1028; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1038; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0569539							
SHORT DESCRIPTION:	KIOSK METER:1PH ;14 KVA ;12 WAY SECURE ; GROUND MOUNT							
TECH. DESCRIPTION: KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 12 WAY SECURE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 12-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH TWELVE 60A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER D-1029; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1029; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0672776							
SHORT DESCRIPTION:	KSK MTR:1PH;14 KVA;12 WAY SECURE NO BASE							
TECH. DESCRIPTION: KIOSK METER: PHASE: 1PH; SUPPLY: 14 KVA; TYPE: 12 WAY SECURE NO BASE; MATERIAL: 3CR12 POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 12-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH TWELVE 60A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AND ACCESS CONTROL EQUIPMENT AS PER DDT-1029; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS ; DRAWING NO: DDT-3236; MNFR DRG: DDT-1029; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021	
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		 D-DT-3236		
				NTS				
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:				
				SERIES 3000				
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		SAP No:		
				3236		0569538 0672776		
						SET	SHEET	REV
						34	24	14

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0688003							
SHORT DESCRIPTION:	KSK MTR:3PH;50 KVA;2 WAY SECURE GRND MNT							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE: 3PH; SUPPLY: 50 KVA; TYPE: 2 WAY SECURE GRND MNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY – C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 2-WAY 50KVA SMALL POWER USERS; EXCLUDING METERS; FULLY FITTED WITH TWO 80A THREE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AS PER D-1040; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: DDT-3236; MNFR DRG: DDT-1040; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
SAP MATERIAL No.:	0688006							
SHORT DESCRIPTION:	KSK MTR:3PH;50 KVA;4 WAY SECURE GRND MNT							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE: 3PH; SUPPLY: 50 KVA; TYPE: 4 WAY SECURE GRND MNT; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY – C35 TO SANS 1091; STANDARD: ESKOM: 240-52840756; FOR SECURE GROUND MOUNT 4-WAY 50KVA SMALL POWER USERS; EXCLUDING METERS; FULLY FITTED WITH FOUR 80A THREE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING, TERMINALS AS PER D-1041; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: DDT-3236; MNFR DRG: DDT-1041; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021	
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE			SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS			0688003	
				CAD REF:	D-DT-3236		SET	SHEET
				SERIES 3000			34	25
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:			REV	
				3236				14

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0569540						
SHORT DESCRIPTION:	KIOSK METER:1PH ;4.6 KVA ;2 WAY ;SECURE ;POLE MOUNT						
TECH. DESCRIPTION:							
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 2 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 2-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH ONE 40A SINGLE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1030; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1030; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>							
SAP MATERIAL No.:	0569541						
SHORT DESCRIPTION:	KIOSK METER:1PH ;4.6 KVA ;4 WAY ;SECURE ;POLE MOUNT						
TECH. DESCRIPTION:							
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 4 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 4-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH TWO 40A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1031; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1031; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>							
SAP MATERIAL No.:	0569542						
SHORT DESCRIPTION:	KIOSK METER:1PH ;4.6 KVA ;6 WAY ;SECURE ;POLE MOUNT						
TECH. DESCRIPTION:							
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 6 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NANY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 6-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH THREE 40A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1032; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1032; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>							
ITEM :- KIOSK SECURE POLE MOUNT							
MATERIAL SPECIFICATION :-							
CORROSION SPECIFICATION :- 240-98195962							
STANDARD SPECIFICATION :-							
ESKOM SPECIFICATION :- 240-55146411, D-DT-1030, 1031, 1032, 1033, 1034							
TEST & CERTIFICATION REQUIREMENTS :-							
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS		0569540	
				CAD REF:		0569541	
				SERIES 3000		0569542	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		SET	SHEET
				3236		34	26


D-DT-3236

14

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:		0569543							
SHORT DESCRIPTION:		KIOSK METER:1PH ;4.6 KVA ;8 WAY ; SECURE ;POLE MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4.6 KVA; TYPE: 8 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 8-WAY 4.6KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH FOUR 40A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1033; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1033; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0569544							
SHORT DESCRIPTION:		KIOSK METER:1PH ;14 KVA ;2 WAY ; SECURE ;POLE MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 2 WAY PM; MATERIAL: 3CR12; POWDER COATED; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 2-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH ONE 100A SINGLE POLE MINIATURE CIRCUIT BREAKER CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1030; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1030; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). ESKOM DRAWING No. D-DT-3236 *									
SAP MATERIAL No.:		0569545							
SHORT DESCRIPTION:		KIOSK METER:1PH ;14 KVA ;4 WAY ; SECURE ;POLE MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 4 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 4-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH TWO 100A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1031; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1031; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
SAP MATERIAL No.:		0569546							
SHORT DESCRIPTION:		KIOSK METER:1PH ;14 KVA ;6 WAY ; SECURE ;POLE MOUNT							
TECH. DESCRIPTION:									
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 6 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 6-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH THREE 100A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1032; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1032; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).									
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021			
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019			
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE	 D-DT-3236		SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS			0569543		0569545
				CAD REF:			0569544		0569546
				SERIES 3000			SET	SHEET	REV
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:			34	27	14
				3236					


Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0569547
SHORT DESCRIPTION:	KIOSK METER:1PH ;14 KVA ;8 WAY ;SECURE ;POLE MOUNT
TECH. DESCRIPTION:	
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 14 KVA; TYPE: 8 WAY PM; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT 8-WAY 14KVA SMALL POWER USERS; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH FOUR 100A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING & TERMINALS AS PER D-1033; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1033; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	

SAP MATERIAL No.:	0571155
SHORT DESCRIPTION:	KSK MTR:3PH;0 KVA;DC SECURE POLE MOUNT
TECH. DESCRIPTION:	
KIOSK METER: PHASE: 3PH; SUPPLY: 0 KVA; TYPE: DC SECURE POLE MOUNT; MATERIAL: 3CR12 POWDER COATED; COLOR: GRAY LIGHT NAVY - C35 SANS 1091; STANDARD: ESKOM: 240-55146411; FOR SECURE POLE MOUNT DATA CONCENTRATOR (DC) KIOSK ; FULLY FITTED WITH FOUR 10A 5KA SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), WIRING AS PER D-1034; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1034; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.				JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420				P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION				BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE NTS	 Eskom			SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF: SERIES 3000				0569547		0571155
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No: 3236	D-DT-3236			SET	SHEET	REV
								34	28	14

Unique Identifier:240-48887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:	0599894						
SHORT DESCRIPTION:	KIOSK METER:3PH ;SUBS ;POLE MOUNT 1 FDR						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: SUBS; TYPE: POLE MOUNT 1 FDR; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-80309303; POLE MOUNT SUBSTATION OUTDOOR METERING PANEL FOR A SINGLE METERING POINT; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-5086; EXCLUDING METERS; INCLUDING FUSE HOLDERS AND FUSES, TEST BLOCKS, 110V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-5806; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0599895						
SHORT DESCRIPTION:	KIOSK METER:3PH ;SUBS ;POLE MOUNT 2 FDR						
TECH. DESCRIPTION:							
KIOSK METER: PHASE QUANTITY: 3PH; SUPPLY: SUBS; TYPE: POLE MOUNT 2 FDR; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-80309303; POLE MOUNT SUBSTATION OUTDOOR METERING PANEL FOR TWO METERING POINTS; FULLY FITTED WITH ALL AUXILIARY EQUIPMENT AS PER D-5805; EXCLUDING METERS; INCLUDING FUSE HOLDERS AND FUSES, TEST BLOCKS, 110V SURGE ARRESTORS, WIRING AND TERMINALS; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-5805; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
SAP MATERIAL No.:	0690283						
SHORT DESCRIPTION:	KSK MTR:3PH;SUBS;1 & 2 FDR BASE						
TECH. DESCRIPTION:							
KIOSK METER: PHASE: 3PH; SUPPLY: SUBS; TYPE: 1 & 2 FDR BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY – C35 TO SANS 1091; STANDARD: ESKOM: 240-80309303; SUBSTATION OUTDOOR METERING PANEL BASE AS PER D-5086; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: DDT-3236; MNFR DRG: DDT-5086; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).							
ITEM :- KIOSK SUBSTATION OUTDOOR POLE MOUNT							
MATERIAL SPECIFICATION :-							
CORROSION SPECIFICATION :- 240-98195962							
STANDARD SPECIFICATION :-							
ESKOM SPECIFICATION :- 240-80309303, D-DT-5805, 5806							
TEST & CERTIFICATION REQUIREMENTS :-							
INSPECTION		Yes	No	ESKOM RELEASE NOTE		Yes	No
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS		0599894	
				CAD REF:		0599895	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	SERIES 3000		SET	SHEET
				FILE No:		34	29
				3236		REV	
				D-DT-3236		14	

Unique Identifier:240-4887441

Revision 1


SPEC SHEET

SAP MATERIAL No.:	0660266							
SHORT DESCRIPTION:	KIOSK METER:1PH ;16 KVA ;2 WAY PREPAY ;GROUND MOUNT							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 2 WAY PREPAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 2 WAY 16KVA SMALL POWER USERS SPLIT PREPAYMENT GROUND MOUNT; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING AND TERMINALS AS PER D-1035; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1035; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0615213							
SHORT DESCRIPTION:	KIOSK METER:1PH ;16 KVA ;4 WAY PREPAY ;GROUND MOUNT							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 4 WAY PREPAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 4 WAY 16KVA SMALL POWER USERS SPLIT PREPAYMENT GROUND MOUNT; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING AND TERMINALS AS PER D-1036; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1036; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
SAP MATERIAL No.:	0615214							
SHORT DESCRIPTION:	KIOSK METER:1PH ;16 KVA ;6 WAY PREPAY ;GROUND MOUNT							
TECH. DESCRIPTION:								
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 6 WAY PREPAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 6 WAY 16KVA SMALL POWER USERS SPLIT PREPAYMENT GROUND MOUNT; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING AND TERMINALS AS PER D-1037; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1037; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).								
ITEM	:- KIOSK MULTIWAY PREPAY GROUND MOUNT							
MATERIAL SPECIFICATION	:-							
CORROSION SPECIFICATION	:- 240-98195962							
STANDARD SPECIFICATION	:-							
ESKOM SPECIFICATION	:- 240-76625427, D-DT-1035, 1036, 1037, 1038, 1039							
TEST & CERTIFICATION REQUIREMENTS :-								
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021		
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	 D-DT-3236		SAP No:		
CHKD:	HPD GROENEWALD	DATE:	01.07.2004			0615212		0615214
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004			SET	SHEET	REV
						34	30	14

Unique Identifier:240-48887441


Revision 1

SPEC SHEET


SAP MATERIAL No.:		0615215								
SHORT DESCRIPTION:		KIOSK METER:1PH ;16 KVA ;8 WAY PREPAY ;GROUND MOUNT								
TECH. DESCRIPTION:										
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 8 WAY PREPAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 8 WAY 16KVA SMALL POWER USERS SPLIT PREPAYMENT GROUND MOUNT; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING AND TERMINALS AS PER D-1038; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1038; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
SAP MATERIAL No.:		0615216								
SHORT DESCRIPTION:		KIOSK METER:1PH ;16 KVA ;12 WAY PREPAY ;GROUND MOUNT								
TECH. DESCRIPTION:										
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 16 KVA; TYPE: 12 WAY PREPAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 12 WAY 16KVA SMALL POWER USERS SPLIT PREPAYMENT GROUND MOUNT; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING AND TERMINALS AS PER D-1039; SUPPLIED WITH TAPERED KIOSK BASE; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: D-3236; MNFR DRG: D-1039; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
SAP MATERIAL No.:		0672778								
SHORT DESCRIPTION:		KSK MTR:1PH;16 KVA;12 WAY PREPAY NO BASE								
TECH. DESCRIPTION:										
KIOSK METER: PHASE: 1PH; SUPPLY: 16 KVA; TYPE: 12 WAY PREPAY NO BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; FOR 12 WAY 16KVA SMALL POWER USERS SPLIT PREPAYMENT GROUND MOUNT; EXCLUDING DIN-RAIL METERS; FULLY FITTED WITH 80A SINGLE POLE MINIATURE CIRCUIT BREAKERS CURVE 1 WITH NO EXPOSED PARTS (TOUCH SAFE), BUSBARS, WIRING AND TERMINALS AS PER DDT-1039; INDELIBLE MNFRS. TRADEMARK AND PART NO. ON ALL ITEMS; DRAWING NO: DDT-3236; MNFR DRG: DDT-1029; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
SAP MATERIAL No.:		0649116								
SHORT DESCRIPTION:		KIOSK METER:1PH ;2 WAY PREPAY ;EMPTY								
TECH. DESCRIPTION:										
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 2 WAY PREPAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 2 WAY SMALL POWER USERS SPLIT PREPAYMENT; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD & BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1035; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).										
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021				
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019				
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS		
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE				SAP No:		
				NTS				0615215	0672778	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF:				0615216	0649116	
				SERIES 3000				SET	SHEET	REV
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:		D-DT-3236		34	31	14
				3236						

SPEC SHEET

SAP MATERIAL No.:		0649117	
SHORT DESCRIPTION:		KIOSK METER:1PH ;4 WAY PREPAY ;EMPTY	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 4 WAY PREPAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 4 WAY SMALL POWER USERS SPLIT PREPAYMENT; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD & BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1036; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0649118	
SHORT DESCRIPTION:		KIOSK METER:1PH ;6 WAY PREPAY ;EMPTY	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 6 WAY PREPAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 6 WAY SMALL POWER USERS SPLIT PREPAYMENT; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD & BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1037; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0649119	
SHORT DESCRIPTION:		KIOSK METER:1PH ;8 WAY PREPAY ;EMPTY	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 8 WAY PREPAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 4 WAY SMALL POWER USERS SPLIT PREPAYMENT; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD & BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1038; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
SAP MATERIAL No.:		0649120	
SHORT DESCRIPTION:		KIOSK METER:1PH ;12 WAY PREPAY ;EMPTY	
TECH. DESCRIPTION:			
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: 12 WAY PREPAY; TYPE: EMPTY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 12 WAY SMALL POWER USERS SPLIT PREPAYMENT; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD & BUSBARS; SUPPLIED WITH TAPERED KIOSK BASE; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1039; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			

14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021			
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019			
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE NTS		 D-DT-3236		SAP No:	
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF: SERIES 3000				0649117	0649119
				FILE No: 3236				0649118	0649120
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004			SET	SHEET	REV	
						34	32	14	

SPEC SHEET

SAP MATERIAL No.:		0672806									
SHORT DESCRIPTION:		KSK MTR:1PH;12 WAY PREPAY;EMPTY NO BASE									
TECH. DESCRIPTION:											
KIOSK METER: PHASE: 1PH; SUPPLY: 12 WAY PREPAY; TYPE: EMPTY NO BASE; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY- C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; EMPTY METER KIOSK FOR 12 WAY SMALL POWER USERS SPLIT PREPAYMENT; FITTED WITH INNER PLATE, DIN RAILS, EARTH STUD & BUSBARS; DRAWING NO: DDT-3236; MNFR DRG: DDT-1039; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).											
SAP MATERIAL No.:		0649121									
SHORT DESCRIPTION:		KIOSK METER:1PH;PREPAY;BASE 2 WAY									
TECH. DESCRIPTION:											
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: PREPAY; TYPE: BASE 2 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK PREPAY BASE 2, 4, 6, 8 WAY; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-DT-1035 SHEET 6; FOR USE WITH STANDARD 2, 4, 6 & 8 MULTI-WAY SPLIT PREPAY METERING KIOSKS; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1035; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).											
SAP MATERIAL No.:		0649122									
SHORT DESCRIPTION:		KIOSK METER:1PH;TAPERED PREPAY;BASE 2									
TECH. DESCRIPTION:											
KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: TAPERED PREPAY; TYPE: BASE 2; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK PREPAY BASE 2, 4, 6, 8 WAY TAPERED; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-DT-1035 SHEET 5; FOR USE WITH STANDARD 2, 4, 6 & 8 MULTI-WAY SPLIT PREPAY METERING KIOSKS; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1035; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE)											
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.		JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021					
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420		P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019					
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS			
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE	<div> Eskom</div> <div>D-DT-3236</div>			SAP No:			
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	NTS				0672806		0649122	
				CAD REF:				0649121			
				SERIES 3000				SET	SHEET	REV	
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No:				34	33	14	
				3236							

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0649123							
SHORT DESCRIPTION:	KIOSK METER:1PH;PREPAY;BASE 12 WAY							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: PREPAY; TYPE: BASE 12 WAY; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK PREPAY BASE 12 WAY; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-DT-1039 SHEET 6; FOR USE WITH STANDARD 12 MULTI-WAY SPLIT PREPAY METERING KIOSKS; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1039; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
SAP MATERIAL No.:	0649124							
SHORT DESCRIPTION:	KIOSK METER:1PH;TAPERED PREPAY;BASE 12							
TECH. DESCRIPTION:								
<p>KIOSK METER: PHASE QUANTITY: 1PH; SUPPLY: TAPERED PREPAY; TYPE: BASE 12; MATERIAL: 3CR12; POWDER COATED; COLOR: LIGHT NAVY GREY - C35 TO SANS 1091; STANDARD: ESKOM: 240-76625427; METER KIOSK PREPAY BASE 12 WAY TAPERED; WITH SIX M10 STAINLESS STEEL BOLTS AND NUTS WELDED ONTO KIOSK BASE; INTERFACING DIMENSIONS TO D-DT-1039 SHEET 5; FOR USE WITH STANDARD 12 MULTI-WAY SPLIT PREPAY METERING KIOSKS; DRAWING NO: D-DT-3236; MNFR DRG: D-DT-1039; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>								
14	SAP NUMBER 0571155 AMENDED, 0688001, 0688003, 0688006, 0672776, 0672778, 0672806 ADDED.			JS	HPD GROENEWALD	HPD GROENEWALD	18.08.2021	
13	0615212 CHANGED TO 0660266 SH.29. 0615212 ALREADY SHOWN ON D-DT-9420			P.A.T.	HPD GROENEWALD	HPD GROENEWALD	03.05.2019	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	
AUTH:	HPD GROENEWALD	DATE:	01.08.2004	SCALE NTS				
CHKD:	HPD GROENEWALD	DATE:	01.07.2004	CAD REF: SERIES 3000				
DRAWN:	P.A. VERMAAK	DATE:	01.07.2004	FILE No: 3236		<div style="display: flex; justify-content: space-between;"> <div style="text-align: center;"> <p style="font-size: 1.2em; font-weight: bold;">D-DT-3236</p> </div> <div style="text-align: center;"> <p>SAP No:</p> <p>0649123</p> <p>0649124</p> </div> </div>		
						SET	SHEET	REV
						34	34	14