

SCOPE OF WORK FOR THE SUPPLY OF DIFFERENTIAL PRESSURE TRANSMITTERS AS PER THE PROVIDED SPECIFICATION:

Description of product that needs to be provided –

Description	Qty
Differential Pressure Transmitters	5

Specification of the required Differential Pressure Transmitters to be supplier:

Description	Quantity	Specification
Differential Pressure Transmitters	5	Range 0-25kPa
		Smart type, 2 wire, 4-20mA output, HART Compliant
		+/- 0.05% of the calibrated span
		Over range protection of the full range
		Operating temperature; 0-300 deg C
		½" BSP or ½" NPT male or equivalent to match existing Stub requirements
		Name plate in SS316, Mounting bracket,
		Calibration certificate of the transmitter to be supplier

Delivery Address:

Eskom - Research, Testing and Development,
Lower Germiston Road,
Rosherville,
Johannesburg,
2094