

## Clarification Q&A

1. Roof slates:
  - a. Kendal accommodation – existing roof slates to be replaced with IBR
  - b. IBR sheets: Must have corrosion protection. Colour samples to be submitted to Eskom for approval prior to installation
2. Eskom does not have any structural drawings for the existing buildings. The only available drawings are architectural floor plans with no detailed sections or roof plans. All dimensions on the floor plans are to be verified by the tenderers
3. The appointed contractor will have to conduct a conditional assessment of the existing the structures and produce a conditional assessment report prior to producing detailed drawings
4. Contractors are required to have 5GB CIDB grading or higher
5. BOQ:
  - a. Contractors reminded that the BOQ is not Works Information. Contractors should read and understand the Works Information, align it with the BOQ and Raise any discrepancies in writing to the Buyer before submitting their final tender offer
  - b. Line items labelled as **'Other' in the BOQ**: Where additional items are required on the BOQ, contractor to give a breakdown on a separate sheet to back up the price "other"
6. Tenderers urged to submit their tenders in three forms: one Original hardcopy, one Copy of the Original, and a USB
7. CPA Will only be applicable on one year anniversary of the contract
8. Contractors requested Cat ladder drawings. This will be forwarded to the contractors together with the updated BOQ.