

CLARIFICATION QUESTION & ANSWER SHEET

Contact Person: Zanele Ramaselele

E-Mail Address: ramasezj@eskom.co.za

Project Title: Replacement of Tutuka Power Station Hydrogen Generating Plant

Enquiry Number: MPTUT10438GX

Response date: 2022/11/10

Clarification no: 05

Clarification:

N o	Document	Section	Page	Requirement	Clarification Questions	Response / Comments
1.	/	/	/	Bund wall	Please provide drawings of the hydrogen receiver / storage vessels bund wall.	Drawings attached: 0.61/14923 0.61/14925 0.61/14926
2.	Revised Invitation to Tender Hydrogen Plant.pdf	1.3 Tender Returnables	15	Reverse e-auction	Confirm that the reverse e-auction training acknowledgement form is not applicable for this tender.	Reverse e-auction for this transaction is not applicable
3.	2.3 Tender Technical Evaluation Strategy for Hydrogen plant final+RH 20220912 (1).pdf and 2.2 Hydrogen Generating Plant Tech Spec (1).pdf	6.2.4 And 3.4.1	12 And 14	Firefighting system And Mechanical plant requirements	<p>There is ambiguity between the <i>scope of works</i> and the <i>technical evaluation criteria</i>: no clear instruction of Firefighting system is mentioned in the SOW (just a statement) or the NEC scope, but it is a topic for technical evaluation scoring.</p> <p>Advise whether the firefighting system/requirement is applicable to this project or if it is excluded:</p> <ul style="list-style-type: none"> IF included – provide the details, terminal points / battery limits for the fire system; 	<p>The Firefighting system is a requirement for the project.</p> <p>Eskom cannot provide details as this forms part of the design by the Contractor. The scope and battery limits will depend on the plant that is proposed and the particular sources of ignition that may exist.</p> <p>The Contractor shall propose a design based on his particular type of plant and shall also design it based on the placement in the H2 plant room.</p>

CLARIFICATION QUESTION & ANSWER SHEET

No.	Document	Section	Page	Requirement	Clarification Questions	Response / Comments
					Provide the scope required for firefighting in this existing building.	The requirement is that it meets the provisions of the Standard.

Regards

Requester's Name: Zanele Ramaselele