

TENDER CLARIFICATION

The supply, deliver and install 15-metre tower at Klipgat substation and supply, deliver and install 35-metre tower at Nonyane substation.

Response Number: 002 Date issued: 14 October 2022	Invitation To Tender No. MWP1633TX
--	---

The following clarification is needed in response to queries and questions raised by Tenderers.

Clarification Request in **BLUE** and Clarification Response in **BLACK**.

Request Number	Clarification / Discussion
01	<p>Since the yard will be fenced from the live apparatus, there is no need to for the Contractor to provide a person with OHRVS accreditation.</p> <p>Eskom response: Correct.</p>
02	<p>Kindly provide the drawing for the CAT ladder foundation</p> <p>Eskom response: Supplier to supply and install – off the shelf item as per specified length - governing parameters included on Scope Of Work (SOW) document</p>
03	<p>Kindly provide the drawing for the support that are required for the cable tray</p> <p>Eskom response: Supplier to supply and install – off the shelf item as per specified length - governing parameters included on SOW document</p>
04	<p>Kindly provide the drawing for the required foundation for the cable tray</p> <p>Eskom response: Supplier to supply and install – off the shelf item as per specified length - governing parameters included on SOW doc</p>
05	<p>Can you provide us with the stone size that are required at the substation?</p> <p>Eskom response: You do not need additional stones, please use the same stones. Correct</p>
06	<p>Kindly provide the required thickness of the cable tray</p> <p>Eskom response: Supplier to supply and install – off the shelf item as per specified length - governing parameters included on SOW doc</p>

07

Could we please request a better-quality Drawing for the 0.35/1020 Antenna mounting brackets. As the one that is supplied in the Scope of work is poor quality.

Eskom response:

A better quality drawing has been uploaded on the National Treasury and Eskom websites