

No.	Article	Page	Tender Requirement	Clarification Request	Response	Remark
1	Reverse Auction to tender - Smart Meters	P11	0621048 METER ELECT SERV:KEYPAD;230 V;80 A;1	We want to know keypad is integrated on the meter or should provide the separated CIU, does last word "1" mean the single phase meter? For the detailed requirement of this type of meter, we only see this, please give us more information.	The Keypad is separate from the meter however you must tender on both meter and keypad Yes single phase	
2	Reverse Auction to tender - Smart Meters	P11	0693612: METER ELECT SERV:PLC;230 V;20 A;1PH	what does 20A means? It is the maximum current, if so, it isn't reasonable. Is it also single phase meter? For the detailed requirement of this type of meter, we only see this,	Yes 20A but can be reprogrammed with a Key change token Also single phase	
3	Reverse Auction to tender - Smart Meters	P11	0621047: INTERFACE:CIU L+G METERING G3 PLC 0615127: METER KWH:L+G ZMG;160 A;RS232+, 485 0615099: METER KWH:L+G ZMG;1/5 A;RS232+, 485	These equipments are from L+G manufacturers, we can't provide them, can we not participate this part?	Yes these are Landis & Gyr Meters	