

	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

To whom it may concern	Date	28 October 2025
	Enquiries	Kim Hughes
	E-mail address	Hughesk@eskom.co.za

Dear Sir/Madam

Request for Enquiry Number	E1979GXPOU
Description	PROVISION OF STANDBY WELDING SERVICES FOR WATERWAYS OUTAGES AT DRAKENSBERG, INGULA AND PALMIET PUMPED STORAGE SCHEMES – PEAKING OPERATING UNIT (10-YEAR TERM CONTRACT)
Tender Questions Closing Date	5 working day before Tender Closing

Item	Questions	Answers	Clarity Published Dates
1.	Will welding be required every 10 years?	No. Over the 10-year contract, 7 outages are planned: 2 at Drakensberg, 3 at Palmiet, and 2 at Ingula.	28/10/2025
2.	Must teams be on site during the full 10-day repair period?	No. Teams will be notified only if NDT confirms a weld repair is required.	28/10/2025
3.	How many CVs per category must be submitted?	Not mandatory at closing. Clarification to be provided.	28/10/2025
4.	Must WPS documents cover all material categories listed?	Submit WPS for Group 3 materials as per ISO/TR 15608.	28/10/2025
5.	Will the tender closing date be extended?	A request has been received. Extension is under consideration pending internal approval and support.	28/10/2025

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30