

**FMS Non-Technical Services KZN056**

	<u>Question</u>	<u>Response</u>
1	<p>Kindly give clarity to the following on the Bill of qtys for the above project under Earthworks Bill no 2</p> <p><b><u>Earth filling supplied by the contractor comp</u></b></p> <p><b><u>Mod AASHTO density</u></b></p> <p>32 G2 Under Floors</p> <p>33 G5 Under Floors</p> <p>34 Backfilling behind retaining walls</p> <p>35 Backfilling to trenches, holes, etc</p> <p>1. The G2 and G5 material what is the required thickness of the layers, cause if we assume its 20mm and 300mm is required then we would have under charged.</p> <p>2. Item 34 and 35 the backfill material, do you want material from commercial source or imported material from borrow pits. If it is import material do you have the type of material.</p>	<p>Item 34 and 35, you can use G7 imported material for these two items.</p>