



9 No.150 Ø x 2000 LONG
P.V.C. PIPES CAST IN CONCRETE

TRANSFORMER PLINTH
FOR DETAILS SEE 0.63/5406

EQUIPMENT ACCESS

EMERGENCY EXIT


PERSONNEL ACCESS

NOTE:
1. PRATLEY BOX 61GA022P001 WILL BE
SITUATED 1.8M ABOVE FLOOR LEVEL. WHERE
THE SUMP PUMP IS SITUATED BELOW
FLOOR LEVEL.

THIS DRAWING HAS BEEN CREATED ON
A C.A.D. SYSTEM. ANY AMENDMENT MUST
BE EFFECTED ON THE SAME SYSTEM.

C.A.D. REF:[101,175]16325E000.R01

LEGEND		
REF.	DESCRIPTION	ALPHA-NUMERIC
A	380V STATION DAM PUMPHOUSE BOARD	61GA
B	SUBSTATION DISTRIBUTION FRAME	
C	SATELLITE P.L.C. UNITS	
E	BATTERY TRIPPING UNIT	20DG004
F	11/0,4kV STATION DAM PUMPHOUSE TRFR.	20ET004
G	11kV STATION DAM BOARD	60EF

1	<i>[Signature]</i>	21/9/86	ALPHA-NUMERIC LEGEND REF.G & BOARD A REVISED, ALARM PANEL REMOVED & NOTE 1 ADDED.	E.H.	<i>[Signature]</i>
0			FIRST ISSUE / EERSTE UITREIKING	SH.	
REV	AUTH MAG	DATE DATUM	REVISION/REVISIES INDEX REF/INDEXSVRWB 84.6:53.1	BY DEUR	CHKD NAGES
0.63					REFERENCE DRAWINGS VERWYSINGSTEKENINGE
DRG.TEK REGISTR			SOUTH AFRICA  SUID-AFRIKA	ESKOM • EVKOM LETHABO POWER STATION STATION DAM PUMPHOUSE ELECTRICAL EQUIPMENT LAYOUT	
CHKD NAGES	BC JOSEPH	18/09 84	APPROVED D v BARSEWISCH	GOEDGEKEUR F B RENCKEN	REV
DRAWN DETEKEN	A DOCHERTY	13/09 84	18/09 84	18/09 84	0.63 / 16325
SCALE SKAAL	1:50				1

SIZE
GROOTTE A3L