



DOOR SCHEDULE									
MARK	QUANTITY	HAND & WALL THICKNESS	FRAME/DOOR TYPE	REFERENCE DRAWING NO.					
D1	1	150 (2000) 125 (300) 125 (200) 125 (200)	1	1					
D2	1	1	1	1					

NOTE: PROVIDE MASTER KEYS INCLUDING ALL CYLINDER LOCKS - AS PER EXIST SPECIFICATION

- LOOSE FIRE CONTROL EQUIPMENT**
1. TYPES OF EXTINGUISHERS SHALL BE CO₂ OR GENERAL PURPOSE. BY POWER. ALL EXTINGUISHERS SHALL BE COMPLETE WITH A CARRYING HANDLE, WALL MOUNTING BRACKET, TUBE AND NOZZLE TO BE EASILY RE-CHARGEABLE.
 2. EXTERNALLY LOCATED EXTINGUISHERS SHALL BE MOUNTED IN A WEATHERPROOF WALL MOUNTED CABINET WITH A LOCKED DOOR HAVING A KEY IN THE DOOR BEHIND A BREAK-GLASS COMPARTMENT.

- NOTES**
1. THE ASH CONVEYOR SUBSTATION ARE TO BE POSITIONED AT SITE ACCORDING TO THE CLIENT'S REQUIREMENTS.
 2. CONCRETE GRADE - STRUCTURAL = 200mm BLINDING = 150mm
 3. ALL EXPOSED CORNERS TO BE 25x25 CHAMFERED.
 4. BRICKWORK OF WALL COMPRESSIVE STRENGTH OF 20MPa WITH A WATER ABSORPTION OF BETWEEN 7% AND 12% LAID IN CLASS II MORTAR.
 5. BRICKWORK IN BOTTOM AND TOP FIRE COURSE AND EVERY FOURTH COURSE IN BETWEEN.
 6. ALL WORK TO BE DONE IN ACCORDANCE WITH SABS 5000 SERIES OF SPECIFICATIONS.
 7. PROVIDE A 40x40x4 ANGLE WEATHER BAR WITH A 20mm STEP-UP AT DOOR ENTRIES.
 8. ALL TERRACE DRAINAGE PIPES TO BE 300mm DIA. CLASS 500 CONCRETE PIPES.
 9. 400 DENOTES HEIGHT OF SLOPED ABOVE STRUCTURAL CONCRETE.
 10. ALL DIMENSIONS, LEVELS & ETC. TO BE VERIFIED BY THE CONTRACTOR ON SITE PRIOR TO THE CONSTRUCTION OF CONCRETE DETAILED ON THIS DRAWING.

0-63 / 55306

02

LETHABO POWER STATION
NEW ASH CONVEYOR SUBSTATION
PLAN, SECTIONS, ELEVATIONS AND DETAILS
G463700/063/2/001

02

REVISION	DATE	BY	CHKD	APP'D	DESCRIPTION
01	07/09/04	DR	DR	DR	ISSUED FOR TENDER
02	07/09/04	DR	DR	DR	REVISION
03	07/09/04	DR	DR	DR	REVISION
04	07/09/04	DR	DR	DR	REVISION
05	07/09/04	DR	DR	DR	REVISION
06	07/09/04	DR	DR	DR	REVISION
07	07/09/04	DR	DR	DR	REVISION
08	07/09/04	DR	DR	DR	REVISION
09	07/09/04	DR	DR	DR	REVISION
10	07/09/04	DR	DR	DR	REVISION
11	07/09/04	DR	DR	DR	REVISION
12	07/09/04	DR	DR	DR	REVISION
13	07/09/04	DR	DR	DR	REVISION
14	07/09/04	DR	DR	DR	REVISION
15	07/09/04	DR	DR	DR	REVISION
16	07/09/04	DR	DR	DR	REVISION
17	07/09/04	DR	DR	DR	REVISION
18	07/09/04	DR	DR	DR	REVISION
19	07/09/04	DR	DR	DR	REVISION
20	07/09/04	DR	DR	DR	REVISION
21	07/09/04	DR	DR	DR	REVISION
22	07/09/04	DR	DR	DR	REVISION