

Annexure K

Technical Evaluation Criteria

| Item | Description | Weighting% |
|------|--|-------------|
| | Adherence to scope of work | |
| 1. | Condition monitoring at various boiler plant levels. <ul style="list-style-type: none"> 7 years related experience on boiler testing, provision of site reference list (40%). 3 years related experience on boiler testing provision of site reference list (30%). 2 years related experience on boiler testing provision of site reference list (20%). | 40% |
| 2. | Probe handling and equipment set-up during testing <ul style="list-style-type: none"> Provide catalogues of instrument that will be used for testing as per the scope of work (20%). Provision of calibration certificates for probes, thermometers, Manometers, Barometers and thermocouples (15%) | 35% |
| 3. | Provision of ISO/EN method or internal work instruction manuals for conducting air heater leakage | 15% |
| 4. | Responsive lead time for mobilising team to go out to site: <ul style="list-style-type: none"> 3 days – Score 10% 5 days – Score 7% days – Score 5 2 weeks or no information provided– Score 0% | 10% |
| | | |
| | Total | 100% |

Note:

Tenderers should achieve a minimum technical evaluation threshold is 85% to be evaluated further for BBBEE and Pricing.