

SPECIFICATION No	Rev
DSG- 314-416	0

KOEBERG NUCLEAR POWER STATION

SPECIFICATIONS ENGINEERING

SPECIFICATION TITLE:

IODINE FILTER CARTRIDGES

PREPARED BY:



D C EVANS

REVIEWED BY:



APPROVED BY:



DATE:

8 JUNE 1995

**ATTACHMENTS - SPECIFICATION
(CLASSIFICATION DATA LIST)**

SPECIFICATION No	REV
DSG-314-416	0

ESKOM

KOEBERG NUCLEAR POWER STATION

PROCUREMENT SPECIFICATION

PRODUCT: IODINE FILTER CARTRIDGES

TECHNICAL DESCRIPTION: IODINE FILTER CARTRIDGE:
minimum collection efficiency
of 90% for organic compounds.

IDENTIFICATION PRODUCT:

Each package is to be marked with:

1. General description of package content.
2. Manufacturer's name and product part/model numbers.
3. ESKOM's NSN number (if applicable).
4. ESKOM's order number.

CERTIFICATION:

The Manufacturer/Supplier is to complete an ESKOM (KOEBERG) CERTIFICATE OF CONFORMANCE certifying that the product supplied meets the requirements of this specification.

- * Manufacturer/supplier shall supply test Certificates, for the filter Cartridges, indicating the collection efficiency for organic compounds.
- * Full details of all deviations from this Specification must be submitted to ESKOM (KOEBERG) in writing for clearance prior to manufacture/despatch of the product.