

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

To tenderers E1598DXMP	Date	11 August 2025
	Enquiries	Olebogeng Mathye
	E-mail address	mathyeo@eskom.co.za

Dear Sir/Madam

Request for Enquiry Number	<u>E1598DXMP</u>
Description / Project Title	<u>The Provision of Lifts in Eskom Park</u>
Tender Questions Closing Date	<u>21 August 2025</u>

Item	Questions	Answers	Clarity Published Dates
1	<p>Amendments:</p> <p>Thulani mentioned that there are 4x passenger lifts, together with the 1x goods lift that form part of the scope of work – both the removal, decommissioning of existing and installation of the new lifts. We have taken the necessary measurements of the 4th passenger lift, together with the one goods lift.</p> <p>Amendments: from 3x passenger lifts to 4x passenger lifts From 3 floors each to 5 floors each</p>	<p>Confirmation: 4x Passenger lifts. From Basement to third floor (All in all 5 floor levels). 1x Goods lift. From basement to Ground floor (2 floor level)</p> <p>Amendments: from 3x passenger lifts to 4x passenger lifts Passenger lifts from 3 floors each to 5 floors each. Goods lift from 3 floor to 2 floors.</p>	18 August 2025
2	<p>Clarity: Regarding the inclusion or exclusion of the “after installation” services such as, but not limited to:</p> <p>Health & Safety, Site Inspection & Annexures, Service/Maintenance plan</p>	<p>We want to know: What support is available and what is included in the offer price for after sales/installation service and for how long.</p>	18 August 2025

3	The current lifts, are they having a motor room or all motors are inside the lift shaft?	They are all in the lift shafts	18 August 2025