

	Business Management System Construction Services Checklist: Fire Equipment Inspection	Document Identifier	240-94015994	Rev	1
		Effective Date	24/10/2022		
		Review Date	24/10/2027		
		Page	1 of 3		

SITE NAME
 CONTRACT No:
 DATE:

Serial No.:

S	Serial No.
S1	
S2	
S3	
S4	
S5	

S	Serial No.
S6	
S7	
S8	
S9	
S10	

S	Serial No.
S11	
S12	
S13	
S14	
S15	

S	Serial No.
S16	
S17	
S18	
S19	
S20	

Equipment:

E	Equipment Type	S	SD	D	M	Q	DATE
E1	DCP Fire Extinguisher						

E	Equipment Type	S	SD	D	M	Q	DATE
E2	Hose Reel						

Notes:

1		3	
2		4	


Deviation Descriptions:

No	Deviation description	No	Deviation description
D1	DCP FIRE EXTINGUISHERS	D2	HOSE REELS
D1.1	Inspection label missing or broken <input type="text"/> <input type="text"/> <input type="text"/>	D2.1	No or damaged symbolic signs <input type="text"/> <input type="text"/> <input type="text"/>
D1.2	Seal missing or broken <input type="text"/> <input type="text"/> <input type="text"/>	D2.2	Equipment due for service <input type="text"/> <input type="text"/> <input type="text"/>
D1.3	No or damaged symbolic signs <input type="text"/> <input type="text"/> <input type="text"/>	D2.3	Label missing or damaged <input type="text"/> <input type="text"/> <input type="text"/>
D1.4	Equipment obstructed inaccessible <input type="text"/> <input type="text"/> <input type="text"/>	D2.4	Reel obstructed or inaccessible <input type="text"/> <input type="text"/> <input type="text"/>
D1.5	Hose and/or nozzle missing or damaged	D2.5	Used for non-fire activities <input type="text"/> <input type="text"/> <input type="text"/>
D1.6	Nozzle hook used for hose and nozzle – nozzle Round and not misformed <input type="text"/> <input type="text"/> <input type="text"/>	D2.6	Not rolled up <input type="text"/> <input type="text"/> <input type="text"/>
D1.7	Pressure guage – high pressure (right hand side pointer up to 28kPa) <input type="text"/> <input type="text"/> <input type="text"/>	D2.7	Corroded or damaged <input type="text"/> <input type="text"/> <input type="text"/>
D1.8	Pressure guage – low pressure (left hand side pointer to 0 kPa) <input type="text"/> <input type="text"/> <input type="text"/>		
D1.9	Operating pressure - working pressure with pointer in green zone <input type="text"/> <input type="text"/> <input type="text"/>		
D1.10	Pressure gauge defective <input type="text"/> <input type="text"/> <input type="text"/>		
D1.11	Equipment due for service <input type="text"/> <input type="text"/> <input type="text"/>		
D1.12	Corroded or damaged <input type="text"/> <input type="text"/> <input type="text"/>		

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Rotek Industries SOC Ltd.

[illegible]

Hard copy printed on: 23/04/2025

	Business Management System Construction Services Checklist: Fire Equipment Inspection	Document Identifier	240-94015994	Rev	1
		Effective Date	24/10/2022		
		Review Date	24/10/2027		
		Page	3 of 3		

Sheq Control/Approval

Designation	Name	Signature	Date
SHEQ Rep			
Site SHEQ Officer			
Supervisor/Manager			

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Rotek Industries SOC Ltd.

Hard copy printed on: 23/04/2025