

## MEMORANDUM

---

To: All Supplier

Reference: Clarification 03 - Tender  
**E1847GXMPMAJ**

From: Hester Kinnear  
Majuba Procurement  
Generation Division

Version: 0

Date: 10 October 2025

**SUBJECT:** Gx Memo – Clarification 03 – **Tender number: E1847GXMPMAJ**  
(Majuba Power Station)

---

### **PURPOSE - Clarification 03 - E1847GXMPMAJ**

#### **Enquiry :**

**Item 6 and 7 have the same part number and description but different material numbers (210802 and 0222862),**

#### **Outcome:**

Item 6: 210802 as per tender

Item 7: -0222862

TRANSMITTER, PRESSURE: RANGE: -100 TO 200 KPA; SUPPLY: 24 V;

CONNECTION: 1/2 IN; SUPPL P/N: EJX510A-DAS8N-019EF

Regards

Majuba Procurement