

Q	A																																													
<p>Noted with thanks. Is it not possible to make an exception this time as the confusion arose from the scope of work being revised subsequent to the clarification meeting which would not allow sufficient time to obtain all the required information and get prices for the spares.</p> <p>Alternatively, please may you assist with the following for the spares needed: Valve series/model number (some series numbers cannot be traced, e.g the THIES 359 and AULD SP06), Material for the relevant spares, Age of the valve. See table below for spares in question:</p> <table><tr><th>Description</th><th>Lift Set Pressure (Kpa)</th><th>Size</th></tr><tr><td>AULD SP06</td><td>2837</td><td>3"</td></tr><tr><td>AULD SP06 Pilot Valve</td><td>2837</td><td>3"</td></tr><tr><td>AULD SP06</td><td>247</td><td>8"</td></tr><tr><td>AULD SP06 Pilot Valve</td><td>247</td><td>8"</td></tr><tr><td>Bailey Birkett 707</td><td>690</td><td>1 1/2"</td></tr><tr><td>Bailey Birkett 707</td><td>1138.5</td><td>1"</td></tr><tr><td>Birkett 1.5E2/2711A5/D</td><td>690</td><td>1 1/2"</td></tr><tr><td>Farris - 26LA21-170</td><td>1310</td><td>3"</td></tr><tr><td>Farris - 26NA11-170</td><td>800</td><td>4"</td></tr><tr><td>Farris 2952</td><td>172.5</td><td>6"</td></tr><tr><td>Hopkinson's 513</td><td>345</td><td>3"</td></tr><tr><td>Leser 526</td><td>1310</td><td>3"</td></tr><tr><td>THIES 359/357</td><td>1310</td><td>3"</td></tr><tr><td>THIES 359/357</td><td>1310</td><td>4"</td></tr></table>	Description	Lift Set Pressure (Kpa)	Size	AULD SP06	2837	3"	AULD SP06 Pilot Valve	2837	3"	AULD SP06	247	8"	AULD SP06 Pilot Valve	247	8"	Bailey Birkett 707	690	1 1/2"	Bailey Birkett 707	1138.5	1"	Birkett 1.5E2/2711A5/D	690	1 1/2"	Farris - 26LA21-170	1310	3"	Farris - 26NA11-170	800	4"	Farris 2952	172.5	6"	Hopkinson's 513	345	3"	Leser 526	1310	3"	THIES 359/357	1310	3"	THIES 359/357	1310	4"	<p>Only Stellite welding was removed from the SOW, no adjustment to spares was made.</p>
Description	Lift Set Pressure (Kpa)	Size																																												
AULD SP06	2837	3"																																												
AULD SP06 Pilot Valve	2837	3"																																												
AULD SP06	247	8"																																												
AULD SP06 Pilot Valve	247	8"																																												
Bailey Birkett 707	690	1 1/2"																																												
Bailey Birkett 707	1138.5	1"																																												
Birkett 1.5E2/2711A5/D	690	1 1/2"																																												
Farris - 26LA21-170	1310	3"																																												
Farris - 26NA11-170	800	4"																																												
Farris 2952	172.5	6"																																												
Hopkinson's 513	345	3"																																												
Leser 526	1310	3"																																												
THIES 359/357	1310	3"																																												
THIES 359/357	1310	4"																																												
<p>We understand that the request was not granted, and we would like to respectfully seek clarification on the decision, particularly as this was impacted by the scope revision during the clarification meeting.</p> <p>We acknowledge Eskom’s commitment to maintaining a fair and transparent procurement process. However, we would appreciate insight into</p>	<p>They are the only company requesting an extension. During the previous tender for this contract, the same company also requested an extension but did not submit a tender, even though the extension was granted.</p>																																													

<p>the rationale behind the decision, especially in light of the potential impact on competitiveness and the quality of the submission.</p> <p>If possible, we kindly request Eskom to reconsider the extension or advise if there are alternative avenues to ensure a compliant and competitive submission.</p> <p>Thank you for your time and consideration. We remain committed to participating in Eskom's procurement processes and appreciate your guidance.</p>	<p>Therefore, we will not grant an extension if they are once again the only company requesting it.</p>
<p>Kindly requesting for site assessment to come and view the safety valves for tender no E1946GXMPACAM so we may be able to quote accordingly,</p> <p>please let us know which time is convenient for you so we can make arrangement to come on site.</p>	<p>The equipment is fully described in the SOW</p> <p>No site visits are required or will be granted</p>