

FRONT VIEW

LEFT SIDE VIEW

NOTES:
1. THE MINIMUM DIMENSIONS OF THE KIOSK ARE SHOWN IN THE DRAWINGS.
2. THE DOOR SHALL BE HINGED AT THE TOP BY AT LEAST TWO HINGES.
3. THE DOOR AND KIOSK SHALL PROVIDE A LIP AND HOLE WHEREBY THE KIOSK CAN BE LOCKED BY A STANDARD ESKOM LOCK.
4. HIGH STRENGTH PLASTIC COMPRESSION CABLE GLANDS SHALL BE PROVIDED FOR THE SUPPLY CABLES.
5. A STANDARD ELECTRICITY DANGER SIGN SHALL BE INPRINTED ONTO THE DOOR (NON-REMOVABLE SIGN - EQUIVALENT TO D-DT-3202).



BOTTOM VIEW

3rd ANGLE

REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.

Eskom

AUTH:
DATE:
CHKD:
DATE:
DRAWN: J.SHINTA
DATE: 21/07/2025

METER KIOSK
POLE TOP 2 WAY
MANUFACTURING DETAIL:
DOOR AND BOTTOM

D-DT-1049

SET	SHEET	REVISION
3	2	A

SIZE GROOTTE A3L