

| Transformer Repairs and Overhauling | | | |
|--|--|--------------------------------------|--------------|
| No. | Item details | Evidence | Score |
| 1 | The workshop with capability of repairing transformers up to and 80 MVA, 132//88/22/11/6.6 KV | AB Schedules | 12.5 |
| | | | |
| 2 | The workshop with a test facility capable of testing transformers up to and 80 MVA, 132, //88/22/11/6.6 KV | AB Schedules | 12.5 |
| | | | |
| 3 | The factory with a crane capable of lifting transformers up to 200 Ton | AB Schedules | 12.5 |
| | | | |
| 4 | Appointed transformer design engineer with more 10 years experience | Submitted CVs (Curriculum Vitae) | 12.5 |
| | | | |
| 5 | Transformer coil winding machines | AB Schedules | 12.5 |
| | | | |
| 6 | Transformer dry -out oven capable up to 80 MVA | AB Schedules | 12.5 |
| | | | |
| 7 | Transformer oil and insulation Testing lab | Sample test report | 12.5 |
| | | | |
| 8 | Paint procedure as per 240-75655504 | Procedure Complies with requirements | 12.5 |
| | | | |
| | Total | | 100 |

Tenderers who do not meet the minimum threshold of 70% will not be evaluated further

NB: A site visit will follow for verification