

HIGH SPEED BFP MOTOR 310 OVERHAUL WORKS: SUMMARY OF TENDER RETURNABLE

Tender returnable shall be adequately referenced with supporting documentation, provided in both hardcopy and softcopy formats.

A. MANDATORY TECHNICAL EVALUATION CRITERIA

Ref #	Mandatory Technical Criteria Description	Tender Returnable
1.	Confirmation that the tenderer can overhaul the motor in situ. YES/NO	Letter stating that the tenderer can overhaul the BFP motor in situ. The letter must be accompanied by at least three previous high speed synchronous motor overhaul data packages that the tenderer conducted.
2.	Confirmation that the tenderer will comply to the MV Motor Refurbishment and Repair of Power Station Electric Motors Works Instruction (240-89217674). YES/NO.	Letter confirming that the tenderer will comply to the MV Motor Refurbishment and Repair of Power Station Electric Motors Works Instruction (240-89217674).

B. QUALITATIVE TECHNICAL EVALUATION CRITERIA

Criteria Ref #	Qualitative Technical Criteria Description	Criteria Weighting (%)	Tender Returnable
1.	Previous Repair/Refurbishment high speed motor overhaul experience.	<u>40</u>	>= 5 Years: 40% >= 3 Years: 30% >= 1 Year: 10% <1 Year: 0%
2.	Previous works: Submission of previous repair/refurbishment works conducted on similar high-speed motors (5600rpm). References for previous projects to accompany the above.	<u>40</u>	<ul style="list-style-type: none">▪ >3 Similar overhauls with references and a short description of activities conducted: 40%▪ >2 Similar overhauls with references and a short description of activities conducted: 20%▪ >1 Similar overhaul with references and a short description of activities conducted: 10% No response or no similarity in previous works conducted with regards to the issued scope: 0%

Criteria Ref #	Qualitative Technical Criteria Description	Criteria Weighting (%)	Tender Returnable
3.	Submission of a complete overhaul repair programme with all activities and duration specified.	<u>20</u>	<21 Days: 20% <24 days: 15% <26 days: 10% >26 days: 0%
TOTAL: 100			

MINIMUM THRESHOLD: >= 70%

