PARTRIDGE, MAUD AND ASSOCIATES CONSULTANTS IN THE EARTH SCIENCES	TRIAL HOLE/TEST PIT	Test Pit No.:10 Sheet:1 of 1
PROJECT: BRAVO		

PROFILE DESCRIPTION



0,00-0,60m Abundant sub-angular to sub-rounded soft and hard rock quartzite GRAVELS, COBBLES and BOULDERS, densely packed in a matrix of yellowish brown SILTY SAND; overall consistency dense; roots; pebble marker.

0,60-1,20m Abundant angular, friable weathered tillite GRAVELS, densely packed in a matrix as above; overall consistency dense; roots; residual tillite.

1,20-2,50m Slightly moist, yellowish grey, in profile pale grey banded and blotched yellow and orange, very stiff, jointed (stained red and black), SANDY SILT containing scattered soft and hard rock gravel to boulder sized clasts; few roots; residual tillite.

2,50-3,60m Pale yellowish brown blotched grey and orange, highly weathered, jointed (stained red and black), very soft rock tillite.

Notes:

1. Pit excavated to refusal of Hyundai 305LC7 excavator at 3,60m on soft rock Dwyka tillite.
2. No water table encountered.
3. No samples taken.

TCP/RLP

16/08/07