


PARTRIDGE, MAUD AND ASSOCIATES CONSULTANTS IN THE EARTH SCIENCES		TRIAL HOLE/TEST PIT	Test Pit No.:20 Sheet:1 of 1
PROJECT: BRAVO			
	PROFILE DESCRIPTION		
	0,00-1,30m	Slightly moist red-brown, in profile red-brown, stiff, micro-fissured SANDY CLAY, with occasional coarse, medium and fine tillite and quartzite GRAVELS, small roots; hillwash.	
	1,30-1,50m	Slightly moist red-brown, in profile yellow-brown mottled red-brown and speckled black, stiff, jointed (stained black and filled with red clay), CLAYEY SAND; residual diabase.	
	1,50-2,30m	Slightly moist yellow-brown, in profile yellow-brown speckled orange-brown and black, dense, jointed (stained black and filled with red clay in places), slightly CLAYEY SILTY SAND; residual diabase.	
	2,30-3,90m	Yellow-brown speckled orange-brown and black, highly weathered, highly fractured (stained red and black with a thin coating of clay in places), very soft rock, diabase, with numerous zones and/or corestones of soft rock up to 0,50m in diameter. Excavates as a friable coarse medium and fine gravel.	
4	<div>Note:<div><div>1.</div><div>Pit excavated to refusal of Hyundai 305LC7 excavator at 3,90m on numerous hard rock diabase corestones.</div></div><div><div>2.</div><div>No water seepage.</div></div><div><div>3.</div><div>Undisturbed samples at 1,00 and 1,80m. Bulk sample (2 bags) from 0,50-1,30m.</div></div></div>		
5	<div>JFR/JFR</div> <div>20/08/07</div>		
6			