


PARTRIDGE, MAUD AND ASSOCIATES CONSULTANTS IN THE EARTH SCIENCES		TRIAL HOLE/TEST PIT	Test Pit No.:3 Sheet:1 of 1
PROJECT: BRAVO			
	PROFILE DESCRIPTION		
	0,00-0,30m	Dry, reddish brown, in profile reddish brown, medium dense, intact, SILTY SAND; roots; hillwash.	
	0,30-1,00m	Abundant mainly sub-angular quartzite and shale GRAVELS densely packed in a matrix as above; roots; pebble marker.	
	1,00-1,50m	Slightly moist, yellowish grey, in profile yellowish brown blotched grey and red, stiff, laminated and jointed CLAY-SILT with pockets of pebble marker gravels as above; few roots; residual Rayton shale.	
	1,50-4,20m	Slightly moist, yellowish grey, in profile grey banded yellow and dark brown, stiff, laminated and jointed (stained red and black) CLAY-SILT; few roots along joints; residual Rayton shale. Shale dips to 25° to SW.	
	4,20-4,90m+	Slightly moist, yellowish grey, in profile grey banded yellow and dark brown, very stiff, laminated and jointed (stained red and black) CLAY-SILT; few roots along joints; residual Rayton shale. Shale dips to 25° to SW.	
5	<div>Notes:</div> <div><div>1.</div><div>Pit excavated to near refusal of Hyundai 305LC7 excavator at 4,90m.</div></div> <div><div>2.</div><div>No water table encountered.</div></div> <div><div>3.</div><div>Bulk sample (2 bags) from 1,50 to 4,90m for foundation indicator, full CBR and saturated consolidometer at 95% Mod. AASHTO testing.</div></div>		
6	<div>TCP/RLP</div> <div>15/08/07</div>		