



CRIMPET 0.54/393 SHT C4	126
CLAMP 0.54/393 SHT C6	144
φ 10 Cu ROD	1400m

- COPPER EARTHING  
TO SPEC ON DRG NO 0.54/393
- INDICATES MAIN EARTHMAT (1 x φ 10)
  - INDICATES EQUIPMENT EARTHING (2 x φ 10)
  - INDICATES CRIMPET CONNECTION SHT C5
  - INDICATES EARTHTAIL CLAMP CONNECTION SHT C7

**DETAILED DESIGN  
NOT FOR CONSTRUCTION**  
ORIGINAL DWG #: N/A  
CONCEPT DWG #: N/A

1	EARTHING & QUANTITIES REVISED.	GT	ALC	MP	13/09/2023
0	FIRST ISSUE.				27/01/2022
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE

Eskom Holdings SOC Ltd  
Reg No 2002/015527/30

UPINGTON MTS  
400kV DIAMETER GC - EARTHING

SoIP21P05-SE-D16	SHEET NUMBER 3A	REVISION 1
------------------	--------------------	---------------