





CRIMPET 0.54/393 SHT C4	46
CLAMP 0.54/393 SHT C6	79
ϕ 10 Cu ROD	708m

- COPPER EARTHING  
TO SPEC ON DRG NO 0.54/393
- INDICATES MAIN EARTHMAT (1 x ϕ 10)
  - INDICATES EQUIPMENT EARTHING (2 x ϕ 10)
  - INDICATES CRIMPET CONNECTION SHT C5
  - INDICATES EARTHTAIL CLAMP CONNECTION SHT C7

**DETAILED DESIGN**  
**NOT FOR CONSTRUCTION**  
ORIGINAL DWG #: N/A  
CONCEPT DWG #: N/A

1	BAY SPACING & EARTHING REVISED.				13/09/2023
0	FIRST ISSUE.	GT	ALG	MP	27/01/2022
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE
 Eskom		Eskom Holdings SOC Ltd Reg No 2002/015527/30			
UPINGTON MTS					
400kv FEEDER 3 BAY - EARTHING					
©					
SolP21P05-SE-D16			SHEET NUMBER	REVISION	
			4A	1	

SKELTON MASTER 0.54/8629 SHEET 06A REV 1