



LARGE/MEDIUM CONTROL ROOMS



SMALL CONTROL ROOMS



- NOTES:
- LARGE CABINET
 - 3 PAIRS OF 75mm BRASS BUTT HINGES
 - 1 SMALL BRASS HASP AND STAPLE TO SUITE
 - 6 x 100mm SCREW AND WALL PLUG TO FIX CABINET TO WALL - 2m TO TOP OF CABINET
 - 1 PADLOCK TO SUITE
 - SMALL CABINET
 - 2 PAIRS OF 75mm BRASS BUTT HINGES
 - 1 SMALL BRASS HASP AND STAPLE TO SUITE
 - 4 x 100mm SCREW AND WALL PLUG TO FIX CABINET TO WALL - 2m TO TOP OF CABINET
 - 1 PADLOCK TO SUITE
 - ENTIRE CABINET TO BE MADE WITH 20mm MERANTI OR EQUAL HARDWOOD. CABINET SHALL BE SANDED DOWN AND SEALED WITH WOODOC 5

3	LARGE CABINET LAYOUT CHANGED	ARN	DBN	DJS	4/6/2004			
2	REDRAWN	ARN	DBN	DJS	17/5/2004			
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	REFERENCE DRAWINGS		
	Eskom Transmission		ESKOM HOLDINGS LIMITED					
APPROVED BY	LF		REG NO.					
DATE	30/6/1980		2002/015527/06					
CHECKED BY	LF		SUBSTATION BUILDINGS					
DATE	30/6/1980		STANDARD DETAILS					
DRAWN BY	JACS		CONTROL ROOM - KEY CABINETS					
DATE	26/6/1980		0.54/1150				SHEET NUMBER	31
SCALE	-----		3				REVISION	3