

CONCRETE ROOF TILES

ALUMINIUM GUTTER
M16 BOLT

MAKE A 60 x 60 OPENING
IN FASCIA TO FIT A
50 x 50 EARTHTAIL CLAMP
SEE DRG. 0.54/393 SHT.C6

φ10mm COPPER ROD FIXED TO CLAMP
SEE DRG. 0.54/393 SHT.C7

φ20mm GALVANISED PIPE
FIXED TO WALL WITH
GALV. SADDLES

φ10mm COPPER ROD FROM MAIN EARTHMAT
TO BE TIED TO EACH INDIVIDUAL GUTTER.

TYPICAL SECTION

NOTES

- ALL EARTHING IN ACCORDANCE WITH 0.54/393 SERIES.
- THE EARTHTAIL CLAMP MUST BE FIXED TIGHTLY AGAINST THE GUTTER
- THE 50 x 50mm AREA OF THE CLAMP AT THE GUTTER MUST BE SANDED TO EXPOSED METAL.
- AFTER THE CLAMP IS FITTED THE AREA AROUND IT MUST BE SEALED WITH SIKA SIKAFLEX F1 TO PREVENT THE INCREASE OF WATER.
- IF GUTTERS IS NOT CONTINUOUS AND IS DEVIDED, EACH MUST BE EARTHED SEPERATELY AND FIXED TO THE MAIN EARTHMAT

EARTHING TO TILED ROOF BUILDINGS

	DRAWN GETEKEN	DBN	JAN 2020	CHKD NAGES		23/7/20	AUTH MAS		23-7-20	REV	0	DATE DATUM
	H V YARD CIVIL WORK STANDARD DETAILS										0.54/393	
												SHEET T19

DRG. TEK
REGISTR

A4L