



ELEVATION

BOTTOM OF DRAINAGE CHANNEL

40mm ACID RESISTANT WASTE PIPE TO DRAIN INTO CHANNEL WITH 90 DEG. BEND IN DIRECTION OF OUTLET. PIPE TO BE 10mm ABOVE CHANNEL SURFACE.

NO.	DESCRIPTION
1.	610 x 455mm WHITE CERAMIC FIRECLAY DRAINER WITH 50mm PVC WASTE.
2.	600 x 400 x 200mm WHITE CERAMIC FIRECLAY LAB SINK WITH 50mm PVC WASTE.
3.	CP COAT HANGER HOOK TO HANG HOSE.
4.	*COBRA* HANDSPRAY SET - 27824SPH, COMPRISING OF - HANDSHOWER AND HIGH PRESSURE FLEXIBLE HOSE WITH G3/4 F1 CP HOSE UNION WINGNUT. *COBRA* STAR HOSE BIPTAP, CP. 107EC-15
5.	22mm COMPRESSION TYPE UNDERWALL STOPTAP, CP. (COBRA 228-15)
6.	PLAIN 160mm CP. BATH SPOUT WITH WALL FLANGE AND CP. EXTENSION PIECE. (COBRA V/C-060CP)
7.	COBRA STAR HOSE BIPTAP, CP107EC-15.

CONTACT: 011 951 5000

NOTES

1. ONLY COLD WATER SUPPLY REQUIRED TO SINK AND SHOWER
2. SAFETY SHOWER & EYEWASH TO BE 310 STAINLESS STEEL SINGLE COLUMN PLATFORM OPERATED UNIT WITH A OVERHEAD AND SECONDARY SPRAY NOZZLES FROM "SPRAYDRENCH" MODEL PO 011*. IF WATER PRESSURE IS NOT THREE BAR, A IN LINE BOOSTER PUMP MUST BE INSTALLED AT THE HEAD TANK. TYPE 'LOWARA STAINLESS STEEL CM70/34' WITH 25L HYDROTUBE & 5 BAR KIT - OR EQUAL APPROVED.
4. IF THIS ARRANGEMENT IS IN A CORNER THE TILES MUST BE EXTENDED WITH 5 VERTICAL ROWS AROUND CORNER.

REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	REFERENCE DRAWINGS
12	SINK OUTLET PIPE EXTENDED TO CHANNEL	DBN			08/02/10	
11	NOTES UPDATED & ADDED HOOK ONTO DRG.	AvdM			03/09/07	
10	NOTE 3 AND DESCRIPTION 4 CHANGED	DBN	DBN	DBN	30/11/06	
9	PLUMBING CHANGED	DBN	DBN	DBN	2/2003	
8	NOTE 3 CHANGED.	DBN	DBN	DBN	2/2003	
0	FIRST ISSUE					

APPROVED BY

R v.d.E.

DATE 2/1996

CHECKED BY

DBN

DATE 2/1996

DRAWN BY

D. NAUDE

DATE 1/12/1995

SCALE 1:20



ESKOM HOLDINGS LIMITED
REG NO. 2002/015527/06

SUBSTATION BUILDINGS

BATTERY ROOM

WASHUP SINK, DRAINER AND SHOWER
STANDARD DETAILS

0.54/1150

SHEET NUMBER

25

REVISION

12