


CRIMPET 0.54/393 SHT C4	118
CLAMP 0.54/393 SHT C6	168
φ 10 Cu ROD	1300m

- COPPER EARTHING  
TO SPEC ON DRG NO 0.54/393
- INDICATES MAIN EARTHMAT (1 x φ 10)
  - INDICATES EQUIPMENT EARTHING (2 x φ 10)
  - INDICATES CRIMPET CONNECTION SHT C5
  - INDICATES EARTHTAIL CLAMP CONNECTION SHT C7

0	BAY EARTHING-STAGE 2 400kV YARD	ALG	EN	AA	22/01/10
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE
		REG NO. 2002/015527/06			
GUMENI					
©	400 kV TRANSFORMER 1 EARTHING				
0.08/19534		SHEET NUMBER 6A		REVISION 0	