



COPPER EARTHING

TO SPEC ON DRG NO 0.54/393

- INDICATES MAIN EARTHMAT (1 x ϕ 10)
- INDICATES EQUIPMENT EARTHING (2 x ϕ 10)
- INDICATES EQUIPMENT EARTHING (50 x 3mm FLAT Cu)
- INDICATES CRIMPET CONNECTION SHT C5
-  INDICATES (1 x ϕ 10) EARTHTAIL CLAMP CONNECTION SHT C7

CRIMPET 0.54/393 SHT C1 NOTE 5	40
CLAMP 0.54/393 SHT C6	43
ϕ 10 Cu ROD	250m

19534	BAY LAYOUT SCHED
19532	FENCE LAYOUT
19531	STLWK MARKING PLAN
19530	EARTHMAT LAYOUT
19529	FDN & TRENCH LAYOUT
19533-2	132kV TUB B/BAR LAYOUT
19533-1	400kV TUB B/BAR LAYOUT
19535	O/H EARTHWIRE LAYOUT
19528	KEY PLAN
19527	STATION ELECTRIC

REV	REVISION DESCRIPTION	REFERENCE DRAWINGS 0.08/	
		ESKOM HOLDINGS LIMITED REG NO. 2002/015527/06	
GUMENI			
132kV TRANSFORMER 1 – EARTHING			
0.08/19534		SHEET NUMBER 32A	REVISION 0