





L.V. CABLES



SECURE CABLE TAG TO MULTICORE CABLES WITH COPPER OR GALVANISED STEEL WIRE OF MIN DIA 1,25mm ON SINGLE CORE CABLES COPPER WIRE IS TO BE USED

M.V. CABLES



5	D.v.B	10.01.89	JOB NO. 651/88 REDRAWN		DHL	I.H		
0			FIRST ISSUE / EERSTE UITREIKING					
REV	AUTH MAG	DATE DATUM	REVISION/REVISIES		BY DEUR	CHKD NAGES	REFERENCE DRAWINGS VERWYSINGSTEKENINGE	
			INDEX REF/INDEKSVERW					
DRG.TEK REGISTR			<div>TRANSMISSION SUBSTATION TECHNOLOGY DEPARTMENT</div> <div></div> <div>ESKOM</div>		CABLE NUMBER TAG DETAILS			
	S. BUCHNER	10/01 89						
CHKD NAGES	I.HILL	10/01 89						
DRAWN GETEKEN	D.H.LEASK	27/12 88	APPROVED D. V BARSEWISCH		GOEDGEKEUR B.E.KELLEY		REV	
SCALE SKAAL							0.00/1290	
				10.01.89		10.01.89	5	