

SINGLE VEE OVERHANG FOR THE END OF SECURITY SLIDING GATE.
(FOR NO. OFF REQ'D - SEE FENCE LAYOUT ON DRG 0.54/7470 SHT.1) 5



VEE OVERHANG FOR CORNER POST





VEE OVERHANG FOR FENCE.
(FOR NO. OFF REQ'D - SEE FENCE LAYOUT)



SINGLE OVERHANG FOR FENCE.
(FOR NO. OFF REQ'D - SEE FENCE LAYOUT)



SINGLE VEE OVERHANG FOR FENCE. 5
(FOR NO. OFF REQ'D - SEE FENCE LAYOUT)



SECTION A - A



DETAIL 2



DETAIL 1



OVERHANG FOR GATE/GATE POSTS.
(10 OFF REQ'D PER GATE/GATE POSTS)

NOTES:

1.) ALL BOLTS, NUTS, WASHERS ETC. REQUIRED FOR ERECTION TO BE SUPPLIED BY THE CONTRACTOR.
2.) ALL STEEL TO BE GRADE 300WA, HOT DIPPED GALVANISED TO SABS 763.
3.) ANY DAMAGE TO THE GALVANISED SURFACES SHALL BE PREPARED WITH AN APPROVED ZINC-METAL SPRAY OR INORGANIC ZINC-RICH PAINT COMPLYING WITH SABS 929. APPLICATION TO SUPPLIERS SPECIFICATIONS.

REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	REFERENCE DRAWINGS
5	TITLE REVISED	PHD	JVT.		27.09.12	SHT 1 ACCESS GATE DTLS
4	VEE OVERHANG FOR SLIDING GATE ADDED	PHD	DBJN.	DBJN.	03.01.12	SHT 2 GATE POST DETAILS
3	VEE OVERHANG FOR CORNER POSTS ADDED	PVG	PVG	DJC.S.	18.11.11	SHT 3 POSTS AND STRUTS DTLS
2	VEE OVERHANG HOLES AND COIL ADDED	DJC.S.	DBJN.	DJC.S.	01.06.09	SHT 4 POST CONC BASES
1	VEE OVERHANG BRACKET ADDED	DJC.S.	DBJN.	DJC.S.	05.07.06	SHT 5 WELDMESH FIXING DTLS
						SHT 6 GATE WIRING PROTECT DTL

APPROVED BY	DJC Senekal
DATE	10.02.2000
CHECKED BY	DBJN.
DATE	02.2000
DRAWN BY	DJC.S.
DATE	02.2000
SCALE	AS SHOWN

Eskom Transmission

ESKOM HOLDINGS LIMITED
REG NO. 2002/015527/06

LEVEL 3 INSTALLATION
2,4m HIGH SECURITY FENCE WITH OVERHANG
OVERHANG BRACKETS
LAYOUT AND DETAILS.

©

0.54/5633	SHEET NUMBER: SHT 7 OF 7	REVISION: 5

SIZE A0L