

Amendment 1

Official Amendment to document 240-50807380 Rev 06 Specification for Gas Insulated Switchgear (GIS) and associated auxiliary equipment

Please ensure that amendment 1 below is read as additional information to points 4.1.5 , 4.2.2.1 & 6.1 of Rev 06 of 240-50807380

Referring to the three sub-sections above, the following must be read in conjunction for clarity recommendation:

In the case where contact status (Isolator or earth switch open or close contact) and hydraulic oil level can not be verified from ground level or from an approved elevated platform which is not in the way of any routine or intrusive maintenance, an alternative method is to be installed and approved.

The recommendation is the installation of a monitor Device (Camera) to be permanently installed and connected to a monitor device or screen. This must be in such a way that the equipment, phase, status or level can be clearly detected without the possibility of wrong identification as well as incorrect status.

Drafted and implemented by:



Frik Schoeman
Senior Technologist, SED

Date: 25 September 2023

Seen and supported by:



Bheki Ntshangase
Senior Manager, SED

Date: 25 September 2023