

LABEL 1



LABEL 2



LABEL 3



LABEL 4



LABEL 5



LABEL 6

(RED, WHITE OR BLUE
COLOUR PHASE DISC)



LABEL 7

JUNCTION BOX LABEL

-SCALE 1:5-



LABEL 8

-SCALE 1:5-



LABEL 9



LABEL 10



LABEL 11

-SCALE 1:5-

NOTES

1. ALL LABELS TO BE MANUFACTURED FROM 1,6mm MILD STEEL PLATE.
2. ALL HOLES TO BE DRILLED BEFORE ENAMELLING. HOLE DIA TO BE SUITABLE FOR THE INSERTION OF BRASS EYELETS AS PER ENLARGED DETAIL.
3. (9) OD OF FIBRE/NYLON WASHERS TO BE MIN 21 MAX 25 - (M10 SCREW) & MIN 17 MAX 21 - (M6 SCREW)



LABEL FIXING DETAIL

M10x30 SET SCREWS WITH NUT,
1 SPRING LOCK WASHER AND
1 FLAT WASHER SUPPLIED WITH
LABEL BRACKETS OR FRAME.

2x FIBRE OR NYLON (NYLON PREFERRED)
WASHERS TO BE SUPPLIED
PER BOLT.

-SCALE 1:1-



LABEL FIXING DETAIL

M6x30 SET SCREWS WITH NUT,
1 SPRING LOCK WASHER AND
1 FLAT WASHER SUPPLIED WITH
LABEL BRACKETS OR FRAME.

2x FIBRE OR NYLON (NYLON PREFERRED)
WASHERS TO BE SUPPLIED
PER BOLT.

-SCALE 1:1-



BRASS EYELET FITTED
AFTER ENAMELLING.
CLEARANCE HOLE TO
SUIT GALVANISED
SCREW. M10 x 30 LG.
FOR LABELS 1 TO 7 & 9

TYPICAL DRILLING DETAIL

-SCALE 1:2-



BRASS EYELET FITTED
AFTER ENAMELLING.
CLEARANCE HOLE TO
SUIT GALVANISED
SCREW. M6 x 30 LG.
FOR LABELS 8 & 11
& BRASS FISCHER PLUG
M6 x 60 LG. FOR LABEL 10

TYPICAL DRILLING DETAIL

-SCALE 1:2-

REV	AUTH MAG	DATE DATUM	REVISION/REVISIES	BY DEUR	CHKD NAGES	REFERENCE DRAWINGS VERWYSINGSTEKENINGE
9	A.A.	14/5/10	LABEL 8, 9, 10 & 11 ADDED. NOTES REVISED.	S.M.N.	C.B.	
8	A.J.S.G	10/2/03	LABEL FIXING NOTES REVISED. NEW ESKOM LOGO ATTACHED.		G.A.C.	
7	A.J.S.G	20/12/94	LABEL FIXING & TYPICAL DRILLING DETAILS REVISED	I.R.	A.D.R	
6	P.C.BRANT	20/5/94	LABEL FIXING DET REV TO SHOW 2 OFF NYLON/FIBRE WASHERS TO BE SUPPLIED BY LABEL MANUFACTURER.	O.J.	P.C.B.	
5	P.C.BRANT	6/8/92	FIXING DETAILS ADDED. DIMENSIONS CHANGED FOR LABEL 1 TO 6 AND NOTES REVISED.		P.C.B.	
4	K.M.P.	5/12/90	LABEL 7 ADDED.		P.B.	
3	K.M.P.	18/11/90	REDRAWN ON CAD	M.J.B.	P.B.	
2	P.J.G.	11/09/78	LABEL 3 HOLES CRS CORRECTED	Z.K.F.	R.J.C.	403 LABEL BRACKET SUPP. DTL.
1	P.J.G.	2/05/78	TWO HOLES ADDED ON LABEL No 3	Z.K.F.	P.J.G.	402 POST SUPPORT & FNDN.
0	—	—	FIRST ISSUE / EERSTE UITREIKING	—	—	400 FRAME & SUPPORT

INDEX REF/INDEKSVERW C3

0.54/–

DRG.TEK REGISTR

CHKD NAGES P.J.GRAHAM 29/04/1970

DRAWN GETEKEN L.CLARKE 29/04/1970

SCALE SKAAL 1:1, 1:2, 1:5 & 1:10

PLOT SCALE - 100:1

WAS 0.00/1692

Eskom Transmission ©

ELECTRICAL EQUIPMENT ENAMELLED LABELS DETAILS

APPROVED P.L.BATTISON 4/05/70

GOEDGEKEUR N.TROOST 15/10/70

0.54/404

REV 9

SIZE GROOTTE A2L

THIS DRAWING HAS BEEN CREATED ON A C.A.D. SYSTEM AND ANY AMENDMENT TO THE DRAWING MUST BE EFFECTED ONLY ON THE SAME C.A.D. SYSTEM