




- ## NOTES
1. ALL WELDING AND WELDING SYMBOLS SHALL CONFORM TO SABS 10044 PART 1 TO PART 5.
 2. ALL STEELWORK TO BE GRADE S355JR, TO SANS 1431 AND HOT DIP GALVANISED TO SANS 121.
 3. ALL WELDS TO BE SEAM WELDED.
 4. ALL STEELWORK TO BE FABRICATED, ERECTED & LEVELLED, TO A TOLERANCE OF + OR - 1,5 mm.
 5. ALL BOLTS SECURING EQUIPMENT TO THIS STRUCTURE, TO BE SUPPLIED BY EQUIPMENT CONTRACTOR.
 6. H.D. BOLTS COMPLETE WITH NUT AND WASHER TO BE SUPPLIED BY CIVIL CONTRACTOR.
 7. HOLES TO BE DIA.18 FOR M16 GRADE 8.8 BOLTS HOT DIP GALVANIZED, UNLESS OTHERWISE STATED.
 8. ALL MARKS TO BE STAMPED ONTO STEELWORK AND SHALL BE CLEARLY LEGIBLE AFTER GALVANISING.
 9. ALL WORK SHALL COMPLY WITH SANS 1200 SERIES SPECIFICATIONS. SPECIFICATIONS: TO FRANCE/DEVIATION TO BE DEGREE OF ACCURACY IT

BOLT SCHEDULE (STRENGTH GRADE 8.8)				
MK	DIA	LENGTH	No OFF	WASHER/BOLT
1	M 16	40	34	1 FLAT

MASS IN kg		
STRUCTURE	BOLTS	TOTAL
400.98	4.62	405.6

0	FIRST ISSUE								
REV	REVISION DESCRIPTION		DRAWN	CHKD	ALTH	DATE	REFERENCE DRAWINGS		
APPROVED BY: 			 Eskom			Eskom Holdings SOC Ltd Reg No 2002/015527/30			
DATE 01 - 06 - 2021									
CHECKED BY: 			<div>132kV ISOLATOR CAP 2ES</div> <div>3m PHASE SPACING</div> <div>MANUAL</div>						
DATE 01/06/2021									
DRAWN BY: A.T.FLOEN									
DATE 17/11/2020			<div>0.54/10103</div>				SHEET NUMBER		REVISION
SCALE 1:20							0		0